



599-2015
RFI RESPONSE No. RFI-0003

**REQUEST FOR QUOTATION DESIGN BUILD OF THE CITY OF
WINNIPEG'S NORTH END SEWAGE TREATMENT PLANT POWER
SUPPLY UPGRADE PROJECT**

URGENT

ISSUED : February 2, 2016

**PLEASE FORWARD THIS DOCUMENT TO
WHOMEVER IS IN POSSESSION OF THE
REQUEST FOR QUALIFICATION**

THE FOLLOWING PROVIDES ANSWERS TO RFI'S FROM PROPONENTS

Proponents are reminded that they are not entitled to rely on this information or interpretation unless and to the extent that it is provided by the Contract Administrator by subsequent addendum. (see B6.3 and B12.4)

- Question 1** If a team member will take all financial and security risk, can there be an exemption for the subcontractors (other "team members") from having to submit their Section F financials, bank letters, surety, etc..
- Answer 1** B33.1 was clarified in Addendum 1.
- Question 2** What role and responsibilities does the City anticipate the Construction Electrical Protection Lead having on this project?
- Answer 2** It is anticipated that the Construction Electrical protections lead will have the responsibility of final verification of settings, commissioning and sign off of protection elements and relays.