



952-2015 ADDENDUM 3

NORTH END SEWAGE TREATMENT PLANT (NEWPCC) HAULED LIQUID WASTE FACILITY PHASE II UPGRADE

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: March 29, 2016
BY: Rob Gillis
TELEPHONE NO. (204) 489-5900

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20150806

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, April 8, 2016.

PART E – SPECIFICATIONS

Revise: Section 25 14 00 Clause 2.21.4 to read: Acceptable panel manufacturer shall be Celco Controls, Manco Control Systems Inc., or Schneider Electric Canada Systems Inc.

Revise: Section 33 47 23 Clause 2.1 to read:

- .1 Provide one of the following:
 - .1 PVC Schedule 80 to CSA B137.3 with solvent weld bell ends.
 - .2 PVC DR25 C-900 to CSA B137.3 with elastomeric seal.
- .2 Provide coupling to existing underground vent pipe using product on the City of Winnipeg Approved Product Underground Use list.

DRAWINGS

Replace: 952-2015_Drawing_1-0101Y-P0006-001-R3 with 952-2015_Addendum_3_Drawing_1-0101Y-P0006-001-R4