



# BID OPPORTUNITY No. 445-2016 ADDENDUM No. 1

## SUPPLY AND DELIVERY OF LARGE DIAMETER BUTTERFLY VALVES WITH ACTUATORS

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: May 13, 2016  
BY: Doug Berg, C.E.T.  
TELEPHONE NO. 204 986-4452

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20150806

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 9 of Form A: Bid may render your Bid non-responsive.**

---

### **PART E – SPECIFICATIONS**

Revise: E4.4 (g) to read: or approved equal in accordance with B6.

Revise: E4.6.2 (a) (ii) to read: The City will provide the Contractor with blind testing flanges for testing the 1200mm diameter butterfly valve and the 1050mm diameter butterfly valve. The blind flanges will remain property of the City upon successful completion of testing. The Contractor shall be responsible for providing all gaskets required for the blind testing flanges.

Delete: E4.6.2 (a) (iii)

Revise: E6.1 (a) to read: The equipment provided in this contract will be installed by other forces at a later date (Fall/Winter of 2016-17) and the Contractor will be required to provide a qualified technical representative to: