


CONTINUED FROM LEFT


P22308 } 24VDC FROM TB21  
C22308 } SEE DWG. 1-0101-ACBD-F212-002

P22309 } 24VDC FROM TB21  
C22309 } SEE DWG. 1-0101-ACBD-F212-002

GENERAL NOTES:



CONTINUED AT RIGHT



FUSE SCHEDULE

TB	IDENTIFIER	SIZE	RATED CURRENT (A) FA
TB4	0P	5x20mm	0.1
TB4	1P	5x20mm	0.1
TB4	2P	5x20mm	0.1
TB4	3P	5x20mm	0.1
TB4	4P	5x20mm	0.1
TB4	5P	5x20mm	0.1
TB4	6P	5x20mm	0.1
TB4	7P	5x20mm	0.1
TB4	8P	5x20mm	0.1
TB4	9P	5x20mm	0.1
TB4	10P	5x20mm	0.1
TB4	11P	5x20mm	0.1
TB4	12P	5x20mm	0.1
TB4	13P	5x20mm	0.1
TB4	14P	5x20mm	0.1
TB4	15P	5x20mm	0.1
TB4	16P	5x20mm	0.1
TB4	17P	5x20mm	0.1
TB4	18P	5x20mm	0.1
TB4	19P	5x20mm	0.1
TB4	20P	5x20mm	0.1
TB4	21P	5x20mm	0.1
TB4	22P	5x20mm	0.1
TB4	23P	5x20mm	0.1
TB4	24P	5x20mm	0.1
TB4	25P	5x20mm	0.1
TB4	26P	5x20mm	0.1
TB4	27P	5x20mm	0.1
TB4	28P	5x20mm	0.1
TB4	29P	5x20mm	0.1
TB4	30P	5x20mm	0.1
TB4	31P	5x20mm	0.1

10	—	—
9	—	—
8	—	—
7	—	—
6	—	—
5	—	—
4	—	—
3	—	—
2	—	—
1	—	—
NO.	DRAWING NUMBER	REFERENCE DRAWING TITLE
REFERENCE DRAWINGS		



B.M. ELEV.			
CONSTRUCTION COMPLETION DATE: YYYY MM DD			
REVISIONS	NO.	DATE	BY
1		2022 07 05	JAS
0		2022 05 18	JAB
		DATE	2022 04 11

**KGS GROUP**

DESIGNED BY	DG	CHECKED BY	JAB
DRAWN BY	RG	APPROVED BY	JAB
SCALE:	NTS	RELEASED FOR CONSTRUCTION	
DATE	2022 04 11	DATE	

ENGINEER'S SEAL	
CONSULTANT DRAWING NUMBER	21-0107-015_A5.136

**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
ENGINEERING DIVISION

**Winnipeg**

NORTH END SEWAGE TREATMENT PLANT (NEWPCC)  
INTERIM PHOSPHOROUS REMOVAL  
AUTOMATION

BUILDING 101  
RIO-F8000-1.R0 WIRING DIAGRAM - DISCRETE INPUT

CITY DRAWING NUMBER 1-0101-ACBD-F214-002

SHEET 7 OF 14