



212-2022 ADDENDUM 1

2022 SEWER RENEWALS BY CIPP LINING (LARGE DIAMETER) – CONTRACT NO. 3

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: May 20, 2022
BY: Rob Sherlock
TELEPHONE NO. 204 478-8993

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, June 9, 2022.

PART E – SPECIFICATIONS

Revise: E7.3.1(c)(i) to read:

- Canora Street –S-MA20015437 – ADWF 25 L/s
- Walnut Street – S-MA20015377 - ADWF 30 L/s
- Maryland Street – S-MA20013620 – ADWF 40 L/s
- Cornish Avenue – S-MA20013653 – ADWF 45 L/s
- Cornish Avenue – S-MA20013706 – ADWF 45 L/s
- St. Mary's Road – S-MA50004096 – ADWF 10 L/s
- St. Mary's Road – S-MA50004097 – ADWF 10 L/s
- St. Mary's Road – S-MA50004085 – ADWF 10 L/s
- Lyndale Drive - S-MA50004084 – ADWF 5 L/s