

**INTERIOR RENOVATION OF BONIVITAL POOL RENEWAL**

**URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: July 8, 2022  
BY: Janelle Fillion, LMAG  
TELEPHONE NO. 204 944-9292

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

**NMS SPECIFICATIONS**

Section 07 42 13.20 Acoustic Barrier Panel System

Add: 1.1.4: Section 23 74 00 Packaged Outdoor HVAC Equipment

Revise: 2.1.1.1.1. to read: dB Noise Reduction Noise Control Enclosure System.  
[www.dbnoisereduction.com](http://www.dbnoisereduction.com)  
Vibro-Acoustics Acoustic Enclosure System.  
[www.vibro-acoustics.com](http://www.vibro-acoustics.com)  
Merlin Noise Control (*alternate*)  
[merlinintegrated.com](http://merlinintegrated.com)

Section 09 65 00 Resilient Flooring

Revise: 2.1.1 to read: .1 Vinyl Sheet (VS): 2.0 mm total thickness, non-cushioned homogeneous sheet vinyl PVC flooring in accordance with ASTM F1913, with polyurethane (PUR) reinforced wear layer composed of 50% binder, 2 m wide rolls, heat welded seams, colour(s) to be selected from manufacturer's entire selection. (RollSmart adhesive).

Add: 2.1.2: .2 Vinyl sheet shall not require periodic polishing, waxing, or applied floor finish treatment products for maintaining original appearance. Periodic dry buffing with rotary machine (max 1500 RPM) is acceptable.

Add: 2.1.3: .3 Basis of Design Products.  
.1 Vinyl Sheet (VS).  
.1 Johnsonite Tarkett iQ Granit.  
.2 Requests for substitutions will be considered subject to specified requirements and in accordance with *B7 Substitutes of the Bidding Procedures*

## **QUESTIONS AND ANSWERS**

Q1: Will there be an extension to the Bid Submission date?

A1: An extension is not being considered at this time.

Q2: Regarding Specification Section 07 42 13.20, Acoustic Aerodynamic Baffles (2.2.4): Is galvanized finish acceptable for the baffles?

A2: Yes, galvanized finished baffles is acceptable.

Q3: Regarding Specification Section 07 42 13.20, Acoustic Aerodynamic Baffles (2.2.4): Is there any direction required for how the baffles will be suspended and hung or is this to be our own design?

A3: The supplemental wall mounted acoustic treatment and aerodynamic baffles spanning the short direction of the enclosure, as shown in the drawings, are for intent only and may not be necessary in order to achieve the performance described in 1.3.2.1. The awarded manufacturer may have their own design to achieve the performance requirements described in 1.3.2.1.

Q4: Regarding Specification Section 07 42 13.20, Finish (2.3): This product will be brought to site prime-coated. Is final finish per Section 09 91 13 to be by others?

A4: The intent is to have the outer faces of the Acoustic Barrier Panel System painted. It is acceptable to have this done by others provided it does not void warranty of the Acoustic Barrier Panel System's scope of work. Performance of the work under Specification Section 09 91 13 is to be coordinated by the General Contractor.

Q5: The change table specified is only good for up to 440 lbs yet the room is designated bariatric and as such should have a change table/lift capable of greater than 600 lbs. Can you please confirm this requirement?

A5: The intent of the project is to meet the City of Winnipeg Accessibility Design Standards as much as practicable. Given the existing spatial constraints, an adult change table of 440lbs load capacity, as specified, is an acceptable adjustment to the user group to meet the intent of the CWADS.

Q6: Will a geotech report be provided?

A6: No, the structural engineer did not require a geotech report be done to complete the design of the Air Handling Unit's housekeeping pad.