



- NOTES:**
- DISCONNECT AND REMOVE EXISTING ELECTRICAL DEVICE AND ALL ASSOCIATED WIRE AND CONDUIT BACK TO SOURCE.
 - EXISTING DEVICE SHALL REMAIN AND BE MAINTAINED.
 - DISCONNECT AND RELOCATE EXISTING SPEAKER AND REMOVE ALL EXISTING WIRE AND CONDUIT. SEE NEW WORK.
 - DISCONNECT AND RELOCATE EXISTING FIRE ALARM DEVICE AND REMOVE ALL EXISTING WIRE AND CONDUIT. SEE NEW WORK.
 - DISCONNECT EXISTING MECHANICAL EQUIPMENT AND REMOVE ALL EXISTING WIRE AND CONDUIT BACK TO SOURCE.
 - EXISTING DEVICES MOUNTED ALONG THE POOL ARE MOUNTED UP AT A HIGH LEVEL AND SHALL BE MAINTAINED UNLESS NOTED OTHERWISE.
 - DISCONNECT EXISTING SAUNA EQUIPMENT.
 - DISCONNECT AND REMOVE EXISTING PANEL A. BRANCH CIRCUIT SHALL BE RELOCATED TO NEW PANEL A LOCATION. SEE NEW WORK.
 - RELOCATE PANEL EM THAT IS PRESENTLY BEING USED AS A JUNCTION BOX AND RELOCATE CONTROLS UP INTO CEILING SPACE.
 - EXISTING PANEL PA SHALL BE RELOCATED TO NEW LOCATION. EXTEND WIRING. SEE NEW WORK.
 - EXISTING DROWNING ALARM PANEL SHALL BE RELOCATED. SEE NEW WORK.
 - EXISTING LIGHTING CONTROL PANEL SHALL BE RELOCATED. EXTEND WIRING TO SUIT. SEE NEW WORK.
 - EXISTING MASTER CLOCK SYSTEM SHALL BE RELOCATED. EXTEND EXISTING WIRING. SEE NEW WORK.
 - RELOCATE EXHAUST FAN CONTROLS TO NEW PANEL A LOCATION.
 - DISCONNECT AND REMOVE EXISTING NETWORK 8000 PANEL CW ALL ASSOCIATED WIRING AND CONDUIT.
 - REMOVE TELEPHONE OUTLET ONCE PAYPHONE HAS BEEN REMOVED.
 - RELOCATE CONDUIT AND OUTLET BOXES FOR DROWNING ALARM ON POOL SIDE TO ACCOMMODATE NEW FURRED OUT WALL.
 - DISCONNECT EXISTING CUH AND RECONNECT NEW ONE IN SAME LOCATION.
 - DISCONNECT EXISTING AC UNIT AND RECONNECT NEW ONE IN SAME LOCATION.
 - DISCONNECT EXISTING SUPPLY FAN AND HEATING COIL AND REMOVE ALL EXISTING WIRING AND CONDUIT.
 - SUPPLY AND INSTALL NEW FIRE ALARM ANNUCIATOR IN EXISTING LOCATION.



2	JULY 13, 2022	ISSUED FOR ADD#06	
1	JUNE 21, 2022	ISSUED FOR CONSTRUCTION	DG
No.	Date	Issue / Revision	By

Drawn By: MFP
Printing Date:

Drawings and specifications, as instruments of service are the property of the architects, the copyright in the same being reserved to them. No reproduction may be made without the permission of the architects, and when made, must bear their names. All prints to be returned.

The contractor is to verify dimensions and data noted herein with conditions on the site and is held responsible for reporting any discrepancy to the architects for adjustment.



**CITY OF WINNIPEG
BONIVITAL POOL RENEWAL**

1215 Archibald St, Winnipeg, MB.

**MAIN FLOOR PLAN
DEMOLITION
POWER & SYSTEMS**

1 MAIN FLOOR PLAN DEMOLITION POWER & SYSTEMS
EDP2.1 SCALE: 1:100