



# 631-2022 ADDENDUM 2

## SUPPLY AND DELIVERY OF LED ROADWAY LIGHTING FIXTURES

### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE  
BID/PROPOSAL**

ISSUED: September 2, 2022  
BY: Vic Hucko  
TELEPHONE NO. 204 986-4191

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID/PROPOSAL AND SHALL FORM  
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

### **FORM B: PRICES**

Replace: 631-2022 Form B: Prices with 631-2022 Addendum 2 - Form B: Prices. The following is a summary of changes incorporated in the replacement Bid/Proposal Submission:

Form B(R1): Revise Item 5 to Acuity, ATB0 P303 MVOLT R2 NL P7

### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, September 16, 2022.

### **PART E – SPECIFICATIONS**

Revise: E2.6 to read: Item No. 5 - Acuity, ATB0 P303 MVOLT R2 NL P7 LED Roadway Lighting Fixture shall be:

Delete: E3.2(d)

Revise: E3.7(a) to read: ANSI C136.41 7- pin receptacle without shorting cap.

Add: E3.8(c) 10kV/5kA TVSS Surge Protection

Add: E3.8(d) IP66 Optical Enclosure Rated

Add: E3.8(e) Dimming Enabled

Add: E3.8(f) 10 Year Warranty

Add: E3.8(g) Packaging – Single Box

Add: E3.8(h) Internal Label Installed Inside

Revise: E4.1(e) to read: Item No. 5 – Acuity, PN: ATB0 P303 MVOLT R2 NL P7

Clarification of E3.8: The features listed in E3.8 are features found on the approved product listed in E4.1. Certain optional features for one manufacturer will be standard features for other manufactures. Clause E3.8 has been updated to clarify the additional features for the approved list.

**QUESTIONS AND ANSWERS**

Q1: For a substitute product does the lumen output have to be the exactly the same as the items listed in the APPROVED PRODUCTS E4?

A1: No. The City understands that outputs may vary from manufacturer to manufacturer. Not withstanding the variations in lumen output all other specifications stated in the Tender and Addendums shall be the same.