



## 996-2022 ADDENDUM 2

### REPAIRS TO FREEDOM ROAD BRIDGES AND ASSOCIATED ROADWORKS

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL**

ISSUED: January 23, 2023  
BY: Michael Penner  
TELEPHONE NO. 204 453-2301

**THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.**

---

#### **PART B – BIDDING PROCEDURES**

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, January 26, 2023.

#### **PART E – SPECIFICATIONS**

Revise: E10.3.3 to read: All treatment shall be in accordance with the latest edition of CSA O80 Series: 21. Timber shall be pressure treated in accordance with Use Category (UC) 4.1 for Highway Structural (critical member) and shall have a minimum net retention of preservative in the lumber of 6.4 kilogram per cubic metre (kg/m<sup>3</sup>). Refer to the A.W.P.A. Manual of Recommended Practices for additional information.

Revise: E14.3 to read: The roadway sign to be supplied and installed is one (1) WA-36L. Sizing to be three hundred (300) mm wide and nine hundred (900) mm high.