



1042-2023 ADDENDUM 2

SUPPLY & SERVICE OF TRANSIT FUELING STATION WITH METHANOL TO HYDROGEN GENERATION

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE
BID/PROPOSAL**

ISSUED: February 27, 2024
BY: Erin Cooke
TELEPHONE NO. 204-226-3557

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID/PROPOSAL AND SHALL FORM
A PART OF THE CONTRACT DOCUMENTS**

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, March 18, 2024.

QUESTIONS AND ANSWERS

- Q1: There is a conflict between the City's request for 225kg per day production capacity stated in E2.8.2(a) and the request for 500kg per day dispensing in E2.8.2(c). Please clarify whether a solution with 225kg or 450kg per day production capacity would be preferred.
- A1: The City has a forecasted demand for 180-200kg of hydrogen per day, as such as a solution that produces 225kg/day is specified by the City. The City will not review alternatives for substantially larger capacity production. The reference to 500kg/day in E2.8.2(c) is in relation to performance specifications for the dispenser. To minimize cost for any future expanded production capacity, the City is requesting a hydrogen dispenser that is capable of dispensing a minimum of 500kg/day. The city fully acknowledges that additional equipment not included in this procurement may be required to physically dispense more than 225kg/day.