



886-2023 ADDENDUM 1

2023 OUTFALL PROGRAM – RIVERGATE DRIVE OUTFALL REHABILITATION

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID/PROPOSAL

ISSUED: November 24, 2023
BY: Nicole Vidal, C.E.T.
TELEPHONE NO. 204 896-1209

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID/PROPOSAL AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: Add 2021-03-05

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid/Proposal, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid/Proposal may render your Bid/Proposal non-responsive.

PART B – BIDDING PROCEDURES

Revise: B3.1 to read: The Bidder is advised that access to the Rivergate Drive Outfall site is restricted as private property authorization is required. As such, the Contract Administrator or an authorized representative will be available on **November 29, 2023** at the below noted timeslot to provide the Bidder's access to the Site. **As the site is currently under active construction, Bidders are requested to park along Rivergate Drive and walk into the Site. Bidders will be required to wear PPE, including high visibility vest, hard hat, and steel toe boots.** Viewing of the Site is not mandatory and is intended to further supplement the Site photos included in the appendices and provide Bidder's a better look at access constraints and existing site conditions.

Site	Date/Time
Rivergate Drive Outfall	November 29, 2023 from 1:00PM to 2:00PM

PART E – SPECIFICATIONS

Revise: E15.3.9 (b) to read: Connections – Weholite HDPE pipe shall be joined by extrusion welding (watertight) in accordance with the manufacturer's instructions and as outlined in ASTM F894 – Standard Specification for Polyethylene (PE) Large Diameter Profile Wall Sewer and Drain Pipe.

APPENDICES

Add: Appendix_C Existing Test Hole Log Information

QUESTIONS AND ANSWERS

Q1: Can you provide borehole/test hole log information?

A1: Yes – See Appendix C. Locations of previous test holes can be referenced in the Record Drawings provided in Appendix B.