



GROUND FLOOR PLAN - LIGHTING
SCALE 1:75

- NOTES:
- BATTERY BANK #1 TO BE RATED AT 230 WATTS FOR 1/2 HOUR.
 - BATTERY BANK #2 TO BE RATED AT 230 WATTS FOR 1/2 HOUR.
 - MOUNT FIXTURES ON WALL 200mm BELOW CEILING TO TOP OF FIXTURE.
 - INSTALL 2-50mm PVC CONDUIT FROM PANEL "RL" UNDER SLAB AND EXTEND 300mm PAST BUILDING LINE. CAP CONDUITS AT EXTERIOR.

REVISIONS		
NO.	DATE	PARTICULARS
1	05-03-23	EXPANDED TENDER

NOTES

SMS ENGINEERING
 SMS Engineering Ltd. Consulting Engineers
 770 Bradford Street Winnipeg MB Canada R3H 0N3
 Telephone: 204.775.0291 Fax: 204.772.2153
 sms@smseeng.com
 03-514-01

PROFESSIONAL SEALS

APEGM
 Certificate of Authorization
 SMS Engineering Ltd.
 No. 166 Expiry: April 30, 2005

ORIGINAL CONTRACT DRAWING
 SIGNED AND SEALED BY
 B. D. LESKO, P. ENG.
 MARCH 23, 2005

THIS DRAWING MUST NOT BE SCALED.
 THE CONTRACTOR SHALL VERIFY ALL DIMENSIONS AND OTHER DATA ON SITE BEFORE COMMENCEMENT OF WORK. ALL DIMENSIONS, TOLERANCES, AND CONDITIONS ARE TO BE REPORTED TO THE ARCHITECT.
 DRAWING AND SPECIFICATIONS, AS INSTRUMENTS OF SERVICE, ARE THE PROPERTY OF THE ARCHITECT. THE COPYRIGHT IN THE SAME BEING RESERVED TO HIM.
 NO REPRODUCTION MAY BE MADE WITHOUT THE PERMISSION OF THE ARCHITECT AND WHEN MADE, MUST BEER HIS NAME. ALL RIGHTS TO BE RETURNED TO THE ARCHITECT ON REQUEST.

200 -141 Bannatyne Avenue, Winnipeg, Manitoba R3B 0G3
 Telephone - 204.936.0938 Facsimile - 204.949.5597

PROJECT TITLE
RED RIVER COMMUNITY CENTRE REDEVELOPMENT

LOCATION
 WINNIPEG, MB
 293 MURRAY AVENUE

CLIENT
 THE CITY OF WINNIPEG

DRAWING TITLE
 Ground Floor Plan
 Mezzanine Floor Plan
 Lighting

DRAWN	APPROVED	DRAWING
RC/CM	ALG	E2.1
SCALE	DATE ISSUED	
1:75	05-03-23	
JOB NUMBER	DATE PLOTTED	REVISION
03-514-01	05-03-23	R-1