



FULL ANGLE SECTION = 12°-22'-26"
 HALF ANGLE SECTION = 6°-11'-13"

AS BUILT

USE TYPE ∇ CEMENT
 INSIDE & OUTSIDE

$P_w = 120 \text{ kPa}$
 $P_t = 168 \text{ kPa}$

SPECIFICATION : AWWA C301 (E)
 TYPE : 'B'
 CLASS/PRESSURE : 120 kPa (17.2 Ps?)
 PLATE THICKNESS : 13 (1/2")
 WIRE MESH—INSIDE : 51 x 102 2.7/2.7 @ 9.5
 WIRE MESH—OUTSIDE : 51 x 203 7.8/4.9 @ 13
 WALL THICKNESS : 95 (3 3/4")

- PLACE 2x4 12/12 WIRE MESH AROUND STIFFENERS
- USE STEEL SPIDERS AT PIPE ENDS TO KEEP PIPE ROUNDS

REV.	DATE:	RECORD OF CHANGE	BY:
B	MAR 29, 79	REVISED TENDER NUMBER	G.L.
A	MAR 8, 79	GENERAL REV. S.P.O.N	G.L.

This drawing and all technical information appearing hereon are the property of CANRON INC. and must be kept in confidence by the recipient. The same may not be used or reproduced either in whole or in part without the express consent of CANRON INC., which reserves all rights of copyright.

CANRON MICROFILMED NOV -- 1981
 INC. PIPE DIVISION

10819-2D-15B
 CITY OF WINNIPEG
 DETAIL OF MK. No: 8
F-1575
15 OF 62

Scale: N.T.S.	Date: 21 AUG. 1978
Drawn by: K.T.	Checked by: C.V.
Approved by: [Signature]	Drawing No. 46-5-8005-15
	Rev. B