


NOTE: CHAINAGES SHOWN ARE ALONG W & E OF LOUELDA ST.



WATER SERVICE INFORMATION

ADDRESS	SIZE(mm)	SIZE(ft)	SHORT & LONG & TYPE & TYPE (STREET) (PROP)	COMP. LOCATION	DR. SERV. W/ BY LOUELDA ST
813 LOUELDA ST	25	25	7.22 NSRL	6.71 S HYD	-
RESIDENTIAL	-	-	-	-	-
824 LOUELDA ST	20	20	5.70 NSRL	NO INFO	-
RESIDENTIAL	-	-	-	-	-
825 LOUELDA ST	25	25	6.10 NSRL	NO INFO	-
RESIDENTIAL	-	-	-	-	-
828 LOUELDA ST	20	20	4.44 NSRL	NO INFO	-
RESIDENTIAL	-	-	-	-	-
829 LOUELDA ST	25	25	7.82 NSRL	NO INFO	-
RESIDENTIAL	-	-	-	-	-
832 LOUELDA ST	20	20	4.57 NSRL	NO INFO	-
RESIDENTIAL	-	-	-	-	-
833 LOUELDA ST	25	25	4.88 NSRL	NO INFO	-
RESIDENTIAL	-	-	-	-	-
836 LOUELDA ST	20	20	4.12 NSRL	3.00 N HYD	-
RESIDENTIAL	-	-	-	-	-
837 LOUELDA ST	25	25	6.40 NSRL	3.28 N HYD	-
RESIDENTIAL	-	-	-	-	-
2 GREEN VALLEY BY	20	20	4.11 NSRL	NO INFO	SEW OFF
RESIDENTIAL	-	-	-	-	GREEN VALLEY BY
3 GREEN VALLEY BY	25	25	4.88 NSRL	NO INFO	SEW OFF
RESIDENTIAL	-	-	-	-	GREEN VALLEY BY
3 TREGAR BY	25	25	5.43 NSRL	6.53 E MV	SEW OFF TREGAR BY
RESIDENTIAL	-	-	-	-	RESIDENTIAL

* SERVICES TO BE REMOVED TO E. ALL OTHERS TO BE RECONNECTED

- CONSTRUCTION NOTES**
1. EXPOSE EXISTING WATERMAIN & CONFIRM INVERTS PRIOR TO CONSTRUCTION.
 2. LOCATE ALL SERVICES IN THE FIELD.
 3. INSTALL WATERMAIN BY TRENCHLESS METHODS.
 4. TRENCHES AND EXCAVATIONS WITHIN 1 METRE OF A PAVED AREA INCLUDING SIDEWALKS SHALL BE CLASS 3 BACKFILL.
 5. ALL MATERIALS SHALL CONFORM TO THE CITY OF WINNIPEG STANDARD CONSTRUCTION SPECIFICATIONS.
 6. MINIMUM COVER TO TOP OF WATERMAIN SHALL BE 2.4 ft.
 7. REPLACE ALL EXISTING LEAD SERVICES FROM PROPOSED WATERMAIN TO E.
 8. NOTIFY ALL AFFECTED RESIDENTS AND BUSINESSES 24 HOURS IN ADVANCE OF ANY WATER SHUTDOWNS OR DISRUPTION OF SERVICE.

WARNING

IF POWER EQUIPMENT OR PERSONS ARE TO BE USED FOR EXCAVATION ON THIS PROJECT THE CONTRACTOR MUST:

- 1) NOTIFY THE GAS COMPANY OF THE PROPOSED LOCATION OF EXCAVATION.
- 2) TAKE PRECAUTION TO AVOID DAMAGE TO GAS COMPANY INSTALLATIONS.

SEE PROVINCIAL REGULATION 216/72 FOR DETAILS



200 WM	WATERMAIN	200 WM	SL - HYDRO	150 WM	WATERMAIN	150 WM	LOCATION APPROVED
HYDRANT	VALVE	50 GAS	TRAFFIC SIGNALS	HYDRANT	VALVE	UNDERGROUND STRUCTURES	
500 LDS	LAND DRAINAGE SEWER	37.5 WWS	WASTEWATER SEWER	50 GAS	LAND DRAINAGE SEWER	37.5 WWS	DATE
MANHOLE	CATCH BASIN	CURB INLET	REDUCER	COUPLER	ANCHOR	EXISTING	PROPOSED
EXISTING	LEGEND-PLAN	PROPOSED	EXISTING	LEGEND-PLAN	PROPOSED	EXISTING	LEGEND-PROFILE

B.M. ELEV.	FIELD BOOK #	CITY OF WINNIPEG
POSTED TO LBS		WATER AND WASTE ENGINEERING DIVISION
DESIGNED BY NC	CHECKED BY TW	
DRAWN BY BAW/DJH	APPROVED BY KZ	
HOR. SCALE 1:250	RELEASED FOR CONSTRUCTION	
VERTICAL 1:50		
NO. REVISIONS	DATE BY	DATE 2005 06 13

ENGINEER'S SEAL

ORIGINAL SIGNED BY K.R. ZUREK 05/06/13

2005 WATERMAIN RENEWALS AND ASSOCIATED WORKS LOUELDA STREET TREGAR BAY TO 90 m NORTH OF TREGAR BAY

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT

SHEET 9 of 12 CITY DRAWING NUMBER D-8760

80 OPPORTUNITY 338-2005 FILENAME: P_8760.dwg PLOT DATE: 2005 06 13