



SIXTH FLOOR

FOURTH FLOOR

1 SINGLE LINE RISER
E-2 SCALE: NTS

- KEY NOTES:
- ① REPLACE EXISTING FUSES WITH 15A FUSES.
 - ② REPLACE EXISTING FUSES WITH 35A FUSES.
 - ③ DISCONNECT TO BE INSTALLED ADJACENT TO FUTURE AC-3 LOCATION (SEE E-1).
 - ④ DISCONNECT TO BE INSTALLED IN FUTURE.

1	ISSUED FOR TENDER	CJH	6/21/05
No.	Revisions	By	Date



SMS ENGINEERING
 SMS Engineering Ltd. Consulting Engineers
 770 Bradford Street Winnipeg MB Canada R3H 0N3
 Telephone 204.775.0291 Fax 204.772.2153
 sms@smseeng.mb.ca

REVIEWED AND APPROVED BY CITY OF WINNIPEG.

Project Title
**THE CITY OF WINNIPEG
 COMPUTER ROOM COOLING UPGRADE
 151 PRINCESS ST. WINNIPEG, MB**

Drawing Title
**DISTRIBUTION DIAGRAM
 MODIFIED SINGLE LINE
 LEVEL 4 AND 6**

Drawn By BTS	Checked By CJH	Approved By CJH
Scale AS NOTED	Date JUNE 2005	File No. 04-169-01
Revision Number 1	Drawing Number E-2	OF 2