



**NOTES:**

- SEE DWGS WP-S0111 TO WP-S0132 FOR SLAB REINFORCING AND WALL ADDITIONAL REBARS, UNO.
- SEE DWG WP-S0515 FOR BEAM AND COLUMN SCHEDULES.
- PROVIDE TEMPORARY WALL BRACING FOR BACKFILLING. DO NOT REMOVE BRACING UNTIL SLAB CONCRETE @ EL 239.09 TO EL 240.55 ATTAINS 28 DAY STRENGTH. THIS APPLIES FOR ALL SIMILAR WALLS BELOW EL 239.950 IN FLOC/DAF AREA.

\* ADDITIONAL BARS WITH FULL EMBEDMENT LENGTH INTO THE INTERSECTING WALLS.

SCALE 1:50 METRES  
SCALE 1:1 MILLIMETRES

 Certificate of Authorization CH2M HILL Canada Ltd. No. 1441 Expiry: April 30, 2006	B.M. ELEV.	 Frederickson Cooper ARCHITECTS	 A Web International Ltd. Company	ENGINEER'S SEAL ORIGINAL SIGNED BY D. KRUGER 2006/02/06	 <b>THE CITY OF WINNIPEG</b> WATER AND WASTE DEPARTMENT ENGINEERING DIVISION WATER TREATMENT PLANT FLOCCULATION AND DAF FOUNDATIONS AND CONCRETE STRUCTURES STRUCTURAL FLOC/DAF AREA 1 SECTION	CITY FILE NUMBER
	00 ISSUED FOR TENDER 2006/02/03 RZ	DESIGNED BY RZ DRAWN BY RL SCALE: 1:50	CHECKED BY AP APPROVED BY DJT RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	CONSULTANT DRAWING NO. WP-S0201		SHEET OF
	NO. REVISIONS DATE BY DATE 2005/07/27 DATE 2006/02/08	DATE 2005/07/27 DATE 2006/02/08	CITY DRAWING NUMBER <b>1-060P-A-50201-001-00D</b>			