



SECOND FLOOR PLAN - SPRINKLER SYSTEM
SCALE: 1/8"=1'-0"

LEGEND	
	QUICK RESPONSE UPRIGHT SPRINKLER
	QUICK RESPONSE SEMI-RECESSED PENDENT SPRINKLER
	METAL SPRINKLER GUARD
	RISER UP
	TEE DOWN
	PIPE DOWN
	FLUSHING CONNECTION
	CONTROL VALVE C/W TAMPER SWITCH
	TEST AND DRAIN CONNECTION. INSTALL 2" DRAIN FROM SUB-BASEMNT TO SECOND FLOOR. PROVIDE CAPPED CONNECTION @ TOP OF RISER.
	SPRINKLER FLOW VALVE

SPRINKLER SYSTEM NOTE:

- 1 ALL CURRENT UPRIGHT SPRINKLER HEADS SHALL BE CONVERTED TO PENDANT STYLE HEADS. NEW SPRINKLER HEADS TO MATCH EXISTING PENDANT STYLE HEADS.
- 2 SPRINKLER WORK NOT INCLUDED IN HATCHED AREA.

NO.	REVISION/DESCRIPTION	BY	DATE
SEALS			

DRAWN BY	RCP	CHECKED BY	APPROVED
DATE	2005.11.17	USER APPROVAL	

CITY OF WINNIPEG
 PLANNING, PROPERTY &
 DEVELOPMENT DEPARTMENT
 CIVIC ACCOMMODATIONS DIVISION
 300 - 65 GARRY ST. R3C 4K4

PROJECT
 ADMINISTRATION BUILDING
 2ND FLOOR RENOVATIONS
 CONVERSION TO OFFICE AREA
 510 MAIN STREET

SHEET TITLE
 SECOND FLOOR PLAN
 SPRINKLER SYSTEM

SCALE	PROJECT NO.	SHEET NO.
AS SHOWN	2004-180-6	M3