



NOTES:

1. EMERGENCY LIGHTING (BATTERIES, LIGHTING HEADS AND RECEPTACLES) SHALL BE MOUNTED 3000mm ABOVE FINISHED FLOOR IN U.V. ROOM AND ELECTRICAL ROOM. ALL OTHER ROOMS, EQUIPMENT TO BE MOUNTED 300mm BELOW CEILING OR UNDERSIDE OF ROOF STRUCTURE.
2. MOTION DETECTORS SHALL BE MOUNTED 3000mm ABOVE FLOOR WHERE POSSIBLE.
3. C.C.T.V. CAMERAS, RECEPTACLES AND COAX JUNCTION BOXES SHALL BE MOUNTED 3000mm ABOVE FLOOR WHERE POSSIBLE. EXTERIOR CAMERA AND ASSOCIATED EQUIPMENT TO BE 5000mm ABOVE FINISHED FLOOR.

FLOOR PLAN – C.C.T.V., FIRE ALARM, SECURITY AND LIGHTING SYSTEMS
SCALE 1:50



B.M. ELEV.	EARTH TECH		ENGINEER'S SEAL ORIGINAL SIGNED BY P. STRYK FEB. 18/05	THE CITY OF WINNIPEG Winnipeg WATER AND WASTE DEPARTMENT		
	Earth Tech (Canada) Inc. Winnipeg, Manitoba 204.477.5381			DESIGNED BY: GSN CHECKED BY: PS DRAWN BY: ERC APPROVED BY: DT	NEWPCC - SECONDARY EFFLUENT UV DISINFECTION FACILITY	
	HOR. SCALE: 1:50 VERTICAL SCALE: 1:50				RELEASED FOR CONSTRUCTION BY: T. KJARTANSON	CITY FILE NUMBER
	0 ISSUED FOR TENDER 05/02/18 JEH			CONSULTANT DRAWING NO. 66303D-CE1.06		CITY DRAWING NUMBER
NO. REVISIONS	DATE	BY	DATE	2005/01/05	DATE	2005-02-18