



UV MODULE 2A & 2B
 TYPE: MEDIUM PRESSURE HIGH INTENSITY
 BANKS: 2
 NO OF LAMPS: 168 PER BANK
 CAPACITY: 143 ML/d
 HEADLOSS @ MAX FLOW: 260 mm



| | | | | |
|---------------------|---|-----------------|---|--|
| B.M. ELEV. | EARTH TECH Earth Tech (Canada) Inc. Winnipeg, Manitoba 204.477.5381 | | ENGINEER'S SEAL | THE CITY OF WINNIPEG Winnipeg WATER AND WASTE DEPARTMENT |
| | DESIGNED BY: CGL | CHECKED BY: DT | ORIGINAL SIGNED BY: D.J. TANIGUCHI | |
| | DRAWN BY: KJW | APPROVED BY: DT | FEB. 18/05 | |
| | HOR. SCALE: VERTICAL SCALE: | | RELEASED FOR CONSTRUCTION BY: T. KJARTANSON | |
| 0 ISSUED FOR TENDER | 05/02/18 | JEH | CONSULTANT DRAWING NO. 66303D-CP1.08 | CITY FILE NUMBER |
| NO. REVISIONS | DATE | BY | DATE 2004/11/03 | DATE 2005-02-18 |
| | | | NEWPCC - SECONDARY EFFLUENT UV DISINFECTION FACILITY | |
| | | | PROCESS UV CHANNEL 2 - MODULES 210/220 | |
| | | | SHEET # OF #S | |
| | | | CITY DRAWING NUMBER | |