



273-2006 ADDENDUM 1

2006 COMBINED SEWER RENEWALS BY CIPP FULL SEGMENT LINING AND CIPP INTERNAL POINT REPAIRS, CONTRACT 16

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: July 12, 2006
BY: Armand Delaurier
TELEPHONE NO. (204) 284-0580

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: E2.4.10 (a)(i) to read: Full segment and partial segment CIPP shall be cured by hot water.

Delete: E3.6.1

Revise: E3.4.8 (a)(i) to read: Internal point repair CIPP shall be ambient or hot water cured.