



**DESIGN LOADS:**

**CRAWLSPACE**

A.) DEAD LOADS:	.1) STRUCTURE SELF WEIGHT	
	.2) SUPERIMPOSED =	0.75 kPa
B.) LIVE LOADS:	.1) OCCUPANCY (ELECT., SAMPLE & CONTROL RMS)	4.8 kPa
	.2) OCCUPANCY (BLOWER RM.)	4.8 kPa



B.M. ELEV.			
01	498-2006 ADDENDUM 2	06/09/22	KK
00	ISSUED FOR TENDER	06/08/28	KK
NO.	REVISIONS	DATE	BY

DESIGNED BY	AP/GGP	CHECKED BY	MK
DRAWN BY	KK	APPROVED BY	AHL
SCALE:	AS SHOWN	RELEASED FOR CONSTRUCTION BY:	R. SOROKOWSKI
DATE	2006/06/16	DATE	2006/08/30

**ENGINEER'S SEAL**

ORIGINAL SIGNED BY: A. POCHANART  
2006/08/30

CONSULTANT DRAWING NO. WG-S0100

**THE CITY OF WINNIPEG**  
WATER AND WASTE DEPARTMENT  
ENGINEERING DIVISION

WATER TREATMENT PLANT  
STANDBY POWER GENERATOR

STRUCTURAL  
PILING PLAN AND FOUNDATION PLAN

CITY FILE NUMBER: [ ]  
SHEET: [ ] OF [ ]  
CITY DRAWING NUMBER: 1-0601G-A-S0100-001-010