




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
0	C-LCP-P37-C01	4-Pair #24 AWG - Cat 5E		CP-P32 DAF Basins 5-8 Control Panel	LCP-P37 DAF Basin 7 VFD Control Panel	DAF Basin 7 VFD Control	
0	C-LCP-P38-C01	4-Pair #24 AWG - Cat 5E		CP-P32 DAF Basins 5-8 Control Panel	LCP-P38 DAF Basin 8 VFD Control Panel	DAF Basin 8 VFD Control	
0	C-LCP-R21-C01	1-Coaxial RG-6		LCP-R21A Residuals Communication Panel	LCP-R21	Residuals Remote I/O	
0	C-LCP-S11-C01	1-Coaxial RG-6		LCP-S11A Bulk Chemical Communication Panel	LCP-S11	Bulk Chemical Remote I/O	Not in Contract 742-2005.
0	C-LCP-T11-C01	1-Coaxial RG-6		LCP-T11A Clearwell Communication Panel	LCP-T11	Clearwell Remote I/O	Not in Contract 742-2005.
0	C-WTPAPRTR01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPAPRTR01	Router/Gateway Network Cable	
0	C-WTPSVES01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVES01	Engineering Workstation Plant Control Network Cable	
0	C-WTPSVES01-C02	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVES01	Engineering Workstation Plant Monitoring Network Cable	
0	C-WTPSVHIS01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVHIS01	Primary Historical Server Network Cable	
0	C-WTPSVHIS02-C01	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPSVHIS02	Standby Historical Server Network Cable	
0	C-WTPSVRVS01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPSVRVS01	Primary Real Time Server Plant Control Network Cable	
0	C-WTPSVRVS02-C01	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPSVRVS02	Standby Real Time Server Plant Control Network Cable	
0	C-WTPSVRVS02-C02	4-Pair #24 AWG - Cat 5E		CP-H32A Backup Server Room Communication Panel	WTPSVRVS02	Standby Real Time Server Plant Monitoring Network Cable	
0	C-WTPWSC11 01-C01	4-Pair #24 AWG - Cat 5E		CP-C11A Polymer Communication Panel	WTPWSC11 01	Local Operator Workstation at CP-C11	
0	C-WTPWSCR01-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR01	Operator Workstation 01 Network Cable	
0	C-WTPWSCR02-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR02	Operator Workstation 02 Network Cable	
0	C-WTPWSCR03-C01	4-Pair #24 AWG - Cat 5E		CP-H31A Primary Server Room Communication Panel	WTPWSCR03	Operator Workstation 03 Network Cable	

NOTES: 	B.M. ELEV.			 		ENGINEER'S SEAL		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION		
	5	498-2006 ADDENDUM 2	06/09/22	BT	DESIGNED BY	SWT	CHECKED BY			SWT
	4	FOR CONSTRUCTION	06/07/28	BT	DRAWN BY	SWT	APPROVED BY	AHL	AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST	SHEET 3 OF 10 CITY DRAWING NUMBER
	3	GENERAL REVISIONS	06/07/13	BT	SCALE: NTS		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI			
	2	742-2005 ADDENDUM 13	06/06/30	BT	DATE 2006/03/29		DATE 2006/03/29			
	1	742-2005 ADDENDUM 6	06/05/25	SWT	DATE 2006/03/29		DATE 2006/03/29			
0	ISSUED FOR TENDER	06/03/29	SWT	DATE 2006/03/29		DATE 2006/03/29				
	NO. REVISIONS	DATE	BY	DATE	2006/03/29	DATE	2006/03/29			