


Pump Schedule								
NO.	SERVICE	LOCATION	MODEL / SIZE	CAP. (gpm) (l/s)	HEAD (ft) (m)	MTR. (HP) (kW)	SPD. (rpm)	REMARKS
P-1	Heating Pump	Mechanical Penthouse	Armstrong 4380 2x2x10	126 7.94	90 27.44	7.5 5.59	1740	VFD Controlled Duty/Standby with P-2
P-2	Heating Pump	Mechanical Penthouse	Armstrong 4380 2x2x10	126 7.94	90 27.44	7.5 5.59	1740	VFD Controlled Duty/Standby with P-1
P-3	Open Number							
P-4	Open Number							
P-5	AHU-1 Coil Pump	Mechanical Penthouse	Armstrong S45	20 1.26	14 4.27	0.25 0.19	1740	
P-6	Open Number							
P-7	Domestic Water Recirculation Pump	Mechanical Penthouse	Armstrong S35 BF	5 0.32	10 3.05	0.167 0.12	1740	
P-8	Sump Pump	Crawlspace	MONARCH SP-33	20 1.26	35 10.67	0.33 0.25	3450	DUTY/STANDBY W/ P-9
P-9	Sump Pump	Crawlspace	MONARCH SP-33	20 1.26	35 10.67	0.33 0.25	3450	DUTY/STANDBY W/ P-8
P-10	Sump Pump	Crawlspace	MONARCH SP-33	20 1.26	35 10.67	0.33 0.25	3450	DUTY/STANDBY W/ P-11
P-11	Sump Pump	Crawlspace	MONARCH SP-33	20 1.26	35 10.67	0.33 0.25	3450	DUTY/STANDBY W/ P-10
P-12	Garage Coil Pump	Garage	Armstrong H32	4.5 0.28	8 2.44	0.167 0.12	1740	
P-13	AHU-2 Coil Pump	Mechanical Penthouse	Armstrong S45	20 1.26	14 4.27	0.25 0.19	1740	

	Pump Schedule	
	Project: Winnipeg Police Service East District Police Station	File: 04-214-01 Date: Apr-07
<i>ISSUED W/ADD'N NO 2</i>	Designer: VSW Sheet: MS-9A	

