



### 673-2006 ADDENDUM 3

#### A PUBLIC – PRIVATE PARTNERSHIP FOR EAST DISTRICT POLICE STATION DEVELOPMENT AND OPERATION

### URGENT

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: May 1, 2007  
BY: Henry Bakker, Number TEN Architectural Group  
TELEPHONE NO. (204) 942-0981

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph D, Proposal Certification may render your Bid non-responsive.

### APPENDIX G – SPECIFICATIONS

Replace: 0 00 10 TABLE OF CONTENTS with attached 00 00 10 (R3), (6 pages).

Revise: Section 08 06 00 DOOR SCHEDULE as follows:

1. Add the following note: "Note 29: All 52mm thick doors, and associated frames are to be constructed as Security Doors and Security Frames as per Specification Section 08 11 00 2.3 and 08 11 00 2.5."
2. Revise Door D-G132 as follows:  
HARDWARE: Add 1 automatic operator, 2 wall switches, 1 power supply.
3. Revise Doors D-G168 and D-G169 as follows (each door):  
HARDWARE: Delete 1 surface bolt, roller latch, flush pulls.  
HARDWARE: Add 1 storeroom lock
4. Revise Door D-G176A as follows:  
HARDWARE: Add 1 4111 closer.
5. Revise Door D-G206 as follows:  
REMARKS: Revise "Privacy Set" to "Office Set".
6. Add gates G-EX102 and G-EX1-4 as follows:  
WIDTH HEIGHT THICKNESS: See Spec.  
TYPE: Cantilevered Gate  
MATL: Alum.  
CARD ACCESS: Yes
7. Add gate G-EX103 as follows:  
WIDTH HEIGHT THICKNESS: 1200 x 2400  
TYPE: Gate  
MATL: Chain Link  
REMARKS: Hardware to accommodate Owner-supplied pad lock.

Add: 08 11 00 2.2.1.9: Stainless Steel: Type 304 stainless steel with No. 4 finish.

Add: 08 11 00 2.2.2.6: Stainless Steel: Type 304 stainless steel with No. 4 finish.

Delete: 08 41 13 2.2.1.1

Revise: 08 41 13 2.2.2 to read: Entrance Doors: Kawneer 500 wide stile doors.

Revise : 08 44 13 2.9.2 to read: All exposed aluminium surfaces: anodized to clear colour, to 0.01 mm (0.4 mil) No. 17 finish.

Revise: 09 95 00 2.1.2.1 to read: Flooring EF-3: Stonehard Stonekote HT4.

Add: 10 09 00 2.16 Car Wash Curtain: Curtain: Vanguard 16 oz. Nylon reinforced vinyl curtain; fungus, rot and U.V. resistant; flame retardant; 50 mm weight pocket along bottom; double stitched hems; track and trolley components shall be a galvanized steel track with 25 mm nylon roller with swivel hook at 300 mm o.c. Mount track to structure with treaded rod connectors and galvanized slotted angle braced back to structure. Mount track minimum 3600 above floor. Curtain length : One (1) curtain (straight run along wall) 6500 mm long and one (1) L shaped 10800 mm long with 100 degree bend. Located ion Garage G-150. Curtain to be maximum 100 mm from floor; distributed by Magikist High Pressure Cleaning Equipment.

Add: 10 09 00 2.16:Floor hatch: Bilco Floor Door; 914 x 914 mm Type T; Aluminium construction with recessed top surface to accept resilient flooring; heavy duty hinges with hold open and release handle. Removable exterior handle. Other acceptable manufacturers: Nystrum FTA.

Delete: Section 32 31 13 CHAIN LINK FENCES AND GATES. In lieu, refer to City of Winnipeg Specification CW 3550(R2).

Add: Section 32 31 33 CANTILEVERED ACCESS GATES (4 pages)

Add: 32 37 00(R1) 2.3.4 Quantity: One (1) Litter Receptacle with Ash Urn

Add: 32 37 00(R2) 2.4.4 Quantity: Six (6) Patio Tables

Add: 32 37 00(R2) 2.5.4 Quantity: Eighteen (18) Patio Chairs

## **DRAWINGS**

Revise: Drawing A0.1

1. On the Drawing List, add the following Revision Sheets issued with this addendum:

<b>Revision Sheet</b>	<b>Drawing Revised</b>
RA-39	L1.1,
RL-1	L3.2
RL-2, RL-3, RL-4	L2.1

Revise Drawing L1.1 as follows:

1. Add symbol for enlarged plan detail at gates G-EX102 and G-EX104 and designate as "RA-39".

Revise Drawing L2.1 as follows:

1. To 3/L2.1, add handrail details, as indicate on Revision Sheet RL-2.
2. To 2/L2.1, add safety nosing and detectable warning surface, as indicated on Revision Sheet RL-3.
3. To L2.1, add safety nosing and detectable warning surface, as indicated on Revision Sheet RL-4.

Revise Drawing L3.2 as follows:

1. To 4/A3, add screen details as indicated on Revision Sheet RL-1.