



673-2006 ADDENDUM No. 7

A PUBLIC – PRIVATE PARTNERSHIP FOR EAST DISTRICT POLICE STATION DEVELOPMENT AND OPERATION

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: May 14, 2007
BY: Henry Bakker, Number TEN Architectural Group
TELEPHONE NO. (204) 942-0981

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20060821

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph Appendix D, Proposal Certification may render your Bid non-responsive.

APPENDIX G - SPECIFICATIONS

- Revise: 12 51 19 2.4.1.1 to read: Manufacturer: Office Specialty
- Revise: 12 51 19 2.4.1.2 to read: Series & Model No: File build-up complete with five (5) 7.5" high drawers, and 25.5" hinged cabinet above with two (2) adjustable shelves. Refer to Revision Sheet RA-40 for sketch.
- Revise: 08 80 00 3.9.3 to read: All other exterior glazing, unless otherwise noted: Type SG-2.
- Revise: 26 52 01 3.1 .7 to read: Charge the batteries and test the system for proper operation (minimum 65 minutes discharge time).
- Revise: 28 23 10 2.2 .11 .1 to read: Software for the interview room systems (9 plus 1 spare) shall be as provided by " For The Record " – FTR, "The Record Reporter" ver. 3.3 or latest version.
- Add: 32 31 33 (Addendum 3) 2.3.2.6: Gate Speed: minimum 0.5 meters/second, opening and closing.

DRAWINGS

Revise: Drawing A0.1

1. On the Drawing List, add the following Revision Sheets issued with this addendum:

Revision Sheet	Drawing Revised
RA-40	none
RM-2	Drawing M3.2

Revise: Drawing A7.2 as follows:

1. 1/A7.2 SECTION THRU BASE DRAWERS AND GUN LOCKERS: Indicate depth of gun lockers as 400mm.

Revise: Drawing M3.2 as follows:

1. Locate fire department connection in Sprinkler Room G194, as indicated on Revision Sheet RM-2.