



FERRIC CHLORIDE FEED PUMP P-S160A

TYPICAL FOR P-S170A, P-S180A, P-S230A, P-S240A, P-S250A, P-S350A, P-S360A, P-S430A, P-S440A.

NOTES

1. MOTOR CABLE SHIELDING SHALL RUN WITHOUT BREAKS FROM THE DRIVE TO THE MOTOR.

 Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007	B.M. ELEV.	 Frederickson Cooper ARCHITECTS	 A Tyco International Ltd. Company	ENGINEER'S SEAL	 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION
	DESIGNED BY: NT DRAWN BY: LAE SCALE: NTS			CHECKED BY: APPROVED BY: AHL RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	
00 ISSUED FOR TENDER 07/01/31 ERC NO. REVISIONS DATE BY DATE		2006/10/31 2007/01/31	2006/10/31 2007/01/31	CONSULTANT DRAWING NO. WS-E0510	WATER TREATMENT PLANT BULK CHEMICAL BUILDING SODIUM HYPOCHLORITE AND CHEMICAL STORAGE BUILDING ELECTRICAL VARIABLE SPEED CHEMICAL FEED PUMP TYPICAL STARTER SCHEMATIC