



SUPPLY FAN SF-H800A

TYPICAL FOR EF-H800A, EF-H801A, SF-H801A, EF-H802A, SF-H802A, SF-H803A, EF-H804A, SF-H804A.

NOTES

- VFD IN MCC AND ALL FIELD WIRING BY DIVISION 16 EXCEPT WIRING TO BAS SYSTEM BY DIVISION 15.
- MOTOR CABLE SHIELDING SHALL RUN WITHOUT BREAKS FROM THE DRIVE TO THE MOTOR.

| | | | | | | | |
|--|---------------------------------------|---|--|------------------|--|---|---------------------------------|
| <p>APEGM Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007</p> | B.M. ELEV. | <p>Frederickson Cooper ARCHITECTS</p> | <p>EarthTech A Tyco International Ltd. Company</p> | ENGINEER'S SEAL | <p>THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION</p> | | |
| | | | | DESIGNED BY: BLM | | CHECKED BY: PS | ORIGINAL SIGNED BY: P. STRYK |
| | | | | DRAWN BY: ERC | | APPROVED BY: AHL | 2007/01/31 |
| | | | | SCALE: NTS | | RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI | CONSULTANT DRAWING NO. WS-E0511 |
| | 00 ISSUED FOR TENDER 07/01/31 ERC | | | | WATER TREATMENT PLANT BULK CHEMICAL BUILDING SODIUM HYPOCHLORITE AND CHEMICAL STORAGE BUILDING | | |
| | NO. REVISIONS DATE BY DATE 2007/01/15 | | | | ELECTRICAL FANS TYPICAL STARTER SCHEMATIC | | |
| | | | | | CITY FILE NUMBER SHEET OF CITY DRAWING NUMBER 1-0601S-H-E0511-001-000 | | |