




REV.	CABLE TAG	CABLE SPECIFICATIONS	LENGTH (m)	FROM	TO	DESCRIPTION	REMARKS
8	C-CP-J11-C02	4-Pair #24 AWG - Cat 5E		CP-J11A Sodium Hypochlorite Communication Panel	CP-J11	Standby Sodium Hypochlorite PLC Plant Control Network Cable	In Contract 792-2006.
8	C-LCP-J12-C01	1-Coaxial RG-6		CP-J11A Sodium Hypochlorite Communication Panel	LCP-J12	Sodium Hypochlorite Remote I/O	In Contract 792-2006.
8	C-LCP-J12-C02	1-Coaxial RG-6		CP-J11A Sodium Hypochlorite Communication Panel	LCP-J12	Sodium Hypochlorite Remote I/O	In Contract 792-2006.
8	C-LCP-S11-C02	1-Coaxial RG-6		LCP-S11A Bulk Chemical Communication Panel	LCP-S11	Bulk Chemical Remote I/O	In Contract 792-2006.

NOTES:	B.M. ELEV.			  		ENGINEER'S SEAL ORIGINAL SIGNED BY S.W. TORMEY 2006/03/29 CONSULTANT DRAWING NO. WH-A0711		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION				
	7	FOR CONSTRUCTION	06/12/01							BT	WATER TREATMENT PLANT PLANT UTILITIES MECHANICAL AND ELECTRICAL	
	6	498-2006 ADDENDUM 6	06/10/13	BT	SHEET 11 OF 11							
	5	498-2006 ADDENDUM 2	06/09/22	BT	AUTOMATION / I AND C PLANT COMMUNICATION CABLES CABLE LIST			CITY DRAWING NUMBER				
	4	FOR CONSTRUCTION	06/07/28	BT				1-0601H-K-A0711-001-08B				
	3	GENERAL REVISIONS	06/07/13	BT	DESIGNED BY			SWT	CHECKED BY	SWT		
	2	742-2005 ADDENDUM 13	06/06/30	BT	DRAWN BY			SWT	APPROVED BY	AHL		
	1	742-2005 ADDENDUM 6	06/05/25	SWT	SCALE: NTS			RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI				
	8	ISSUED FOR TENDER	07/01/22	BT	DATE			2006/03/29	DATE	2006/03/29		
	NO.	REVISIONS	DATE	BY	DATE			2006/03/29	DATE	2006/03/29		



January 12, 2007