



ADDENDUM 2 BID OPPORTUNITY 793-2006

WINNIPEG WATER TREATMENT PROGRAM – CONSTRUCTION OF WATER TREATMENT PLANT BUILDING ENVELOPE

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: April 11, 2007
BY: Gord Smith, P. Eng.
TELEPHONE NO. (204) 986-4249

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace 793-2006_Bid_Submission with 793-2006_Addendum_2-Bid_Submission. Form G2 has been replaced by Form G2(R1).

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 12:00 noon Winnipeg time, April 17, 2007.

PART D – SUPPLEMENTAL CONDITIONS

Revise: D2.2 to read: The major components of the Work include but are not limited to:

- (a) Supply and Installation of all masonry work including concrete masonry units, stone masonry units, metal fabrications, joint sealants at masonry work, steel doors and frames, coiling doors, glass and glazing;
- (b) Supply and Installation of all Metal Cladding, including aluminum cladding to columns and soffit areas, rough carpentry, self-adhering waterproofing, building insulations, air barriers, firestopping and smoke seals, joint sealants between metal cladding work and between metal cladding and other work;
- (c) Supply and Installation of aluminium curtain wall and entrances.
- (d) The City will apply and pay for the Building Permit. All other permits are the Contractor's responsibility.

PART E – SPECIFICATIONS

Section 04090

Revise: 2.1.2 to read: Control Joint Filler: Purpose made, rubber, size and shape to suit end use as recommended by manufacturer, Rapid and Regular Control Joint by Dur-O-Wall.

Section 05410

This Section has been added and forms part of this Addendum.

Section 07400

Add: 2.1.2.1.3 Aluminum Colour 3: Duranar XLUC55028XL Bright Silver Metallic by PPG.

Section 08335

Clarification: Doors specified are required to be insulated doors but not rated doors.

Section 08900

Revise: 2.9.1.1.1 to read: Delete "UC51131XL" and replace with "UC55028XL".

DRAWINGS

Clarification: Detail C on Drawing WB-B0404 shows a 16 gauge galvanized skirt cladding assembly extending from 300 below grade up to the underside of the ledger angle. This is to be provided by the Contractor in all areas where metal cladding is show.

The following Drawings have been added and form part of this Addendum:

<u>Consultant Drawing No.</u>	<u>City Drawing No.</u>	<u>Drawing Name/Title</u>
SK1		PROCESS AREA CODES
WB-S6201	1-0601B-A-S6201-001-00D	STRUCTURAL – OVERALL BUILDING – SECTION DETAILS
WB-S6451	1-0601B-A-S6451-001-00D	STRUCTURAL – STANDARD DETAILS
WB-S6202	1-0601B-A-S6202-001-00D	STRUCTURAL – OVERALL BUILDING – LOUVRE SECTIONS

The following Drawings have been revised and form part of this Addendum:

<u>Consultant Drawing No.</u>	<u>City Drawing No.</u>	<u>Drawing Title</u>
WB-B0140	1-0601B-A-B0140-001-01D	ARCHITECTURAL – PENTHOUSE FLOOR PLAN
WB-B0250	1-0601B-A-B0250-001-02D	ARCHITECTURAL - WALL SECTIONS
WB-B0251	1-0601B-A-B0251-001-02D	ARCHITECTURAL - WALL SECTIONS
WB-B0253	1-0601B-A-B0253-001-02D	ARCHITECTURAL - WALL SECTIONS
WB-B0254	1-0601B-A-B0254-001-02D	ARCHITECTURAL – WALL SECTIONS
WB-B0301	1-0601B-A-B0301-001-01D	ARCHITECTURAL - EXTERIOR ELEVATIONS
WB-B0404	1-0601B-A-B0404-001-02D	ARCHITECTURAL - DETAILS
WB-B0503	1-0601B-A-B0503-001-02D	ARCHITECTURAL - DOOR SCHEDULE HEAD & JAMB DETAILS