



*NOTE 1
TIDEFLEX DUCKBILL CHECK VALVE

FeCl₃ BULK TANKS
 QTY: 4
 CAPACITY: 94m³ EACH
 DIMENSIONS: 4.0m ϕ x 8.5m H
 MATERIAL: FIBERGLASS

CONTAINMENT

 APEGM Certificate of Authorization Earth Tech Canada Inc. No. 730 Expiry: April 30, 2007	B.M. ELEV.	 CH2M HILL Frederickson Cooper ARCHITECTS	 EarthTech A Tyco International Ltd. Company	ENGINEER'S SEAL	 THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT ENGINEERING DIVISION		
				DESIGNED BY SBW		CHECKED BY NT	ORIGINAL SIGNED BY S.B. WILLIAMSON
				DRAWN BY JBC		APPROVED BY AHL	2007/01/31
				SCALE: NONE		RELEASED FOR CONSTRUCTION BY: R. SOROKOWSKI	CONSULTANT DRAWING NO. WS-P0006
	NO. REVISIONS	DATE	DATE	2005/08/15	2007/01/31	WATER TREATMENT PLANT BULK STORAGE SODIUM HYPOCHLORITE AND CHEMICAL STORAGE BUILDING	CITY FILE NUMBER
						PROCESS FERRIC CHLORIDE FEED SYSTEM 2 OF 3 PROCESS AND INSTRUMENTATION DIAGRAM	SHEET OF
							CITY DRAWING NUMBER
							1-0601S-G-P0006-001-03D