



Bid Opportunity No. 278-2007 ADDENDUM No. 3

TRANSIT DEPARTMENT PETROLEUM STORAGE AND HANDLING SYSTEMS REPLACEMENT.

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: May 25, 2007
BY: Lorne Stone
TELEPHONE NO. (204) 956-0980

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

SPECIFICATIONS

Revise Section 02115, clause 2.5.1.2.2 to read.

“The waste oil storage tank in concrete vault is not to be removed but is to be abandoned in place. The tank is to be cleaned and purged of vapours, piping removed and tank filled with lean concrete or ECO Fill Grout as approved by Manitoba Conservation, to displace all air from tank. The size of the tank is approximately 35,000 litres.”