


CONT'D ON DWG. 1-0101M-A-E0010-001


NEWPCC SITE PLAN BASEMENT LEVEL CONT'D
1:200



NO.	DRAWING NOTES
1	MAINTAIN AT LEAST 1.05 CABLE DIAMETER SPACING BETWEEN CABLES AT ALL TIMES.
2	INSTALL EXPANSION JOINTS ON ALL CABLE TRAY RUNS, WHERE TRAY CROSS BUILDING EXPANSION JOINTS, AND AS REQUIRED TO ALLOW FOR THERMAL EXPANSION OF TRAY.




4 E0012-001 NEW BANK 2 TECK CABLES. SEE NOTE 1
EXIST. MISC. LOW VOLTAGE CABLES



C GALLERY 1 SECTION
1:30

- 1) 2" POWER CONDUIT
- 2) 1 x MISC POWER CABLE
- 3) 1 x CAT5 CABLE
1 x MISC CONTROL CABLE
- 4) 12 x MISC POWER CABLES
- 5) EMPTY
- 6) EMPTY
- 7) 1-1/4" POWER CONDUIT
- 8) 350MCM 3C 5KV TECK TO MAIN BLDG
- 9) 350MCM 3C 5KV TECK TO MAIN BLDG

D GRIT BLDG WEST DUCT BANK
1:30



KEYPLAN
N/S

B.M. ELEV.	FIELD BOOK #:	SNC-LAVALIN Engineers & Constructors		SNC-LAVALIN 148 Nature Park Way Winnipeg, Manitoba Canada R2P 0Y7	
POSTED TO LBIS		DESIGNED BY C. REIMER	CHECKED BY C. ASMUNDSON	ENGINEER'S SEAL	
		DRAWN BY A. OLIVER	APPROVED BY C. REIMER	PRELIMINARY NOT TO BE USED FOR CONSTRUCTION	
		HOR. SCALE AS NOTED	RELEASED FOR CONSTRUCTION	THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT	
		VERTICAL AS NOTED		NORTH END WATER POLLUTION CONTROL CENTRE MAIN BUILDING FEEDER REPLACEMENTS SITE PLAN 5KV FEEDER ROUTE	
00 ISSUED FOR TENDER	2007/06/22	DATE	2007/03/05	CITY DRAWING NUMBER	
NO. REVISIONS	DATE	BY	FILENAME: 1-0101M-A-E0010-001-00D.dwg	1-0101M-A-E0010	
				SHEET	REV.
				002	00
				SIZE	D