


2 MAIN BUILDING PLAN
E010-001 1:50



B.M. ELEV.	FIELD BOOK #:
POSTED TO LBIS	
DESIGNED BY C. REIMER	CHECKED BY C. ASMUNDSON
DRAWN BY A. OLIVER	APPROVED BY C. REIMER
HOR. SCALE 1:50	RELEASED FOR CONSTRUCTION
VERTICAL 1:50	
00 ISSUED FOR TENDER	2007/06/22 YOM
NO. REVISIONS	DATE BY
	DATE 2007/03/08
	DATE

SNC-LAVALIN Engineers & Constructors		SNC-LAVALIN 148 Nature Park Way Winnipeg, Manitoba Canada R3P 0J7	
ENGINEER'S SEAL		PRELIMINARY	
NOT TO BE USED FOR CONSTRUCTION		THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT	
NORTH END WATER POLLUTION CONTROL CENTRE MAIN BUILDING FEEDER REPLACEMENTS CABLE ROUTING PLAN BANK 1 - 5KV FEEDER		CITY DRAWING NUMBER 1-0101M-A-E0011	
SHEET 002		REV. 00	
SIZE		D	


NO.	DRAWING NOTES
1	SUPPORT BANK 1 TECC CABLES ON UNISTRUT CHANNELS AS SHOWN IN DETAIL 2 OF DRAWING 1-0101M-D-0012-001. MAINTAIN A MINIMUM OF 1.05 CABLE DIAMETER SPACING BETWEEN CABLES OVER THE ENTIRE ROUTE.
2	INSTALL 300mm CABLE TRAY
3	REPAIR AND SEAL WALL AROUND CABLE TRAY.
4	SUPPORT BANK 1 TECC CABLES AS SHOWN IN DETAIL 1 OF DRAWING 1-0101M-D-0012-001. MAINTAIN A MINIMUM OF 1.05 CABLE DIAMETER SPACING BETWEEN CABLES OVER THE ENTIRE ROUTE.



713 DETAIL



712 DETAIL



707 DETAIL



732 DETAIL



710 DETAIL

APEGM
Certificate of Authorization
SNC-Lavalin Engineers & Constructors Inc. (MB)
No. 2365 Expiry: April 30, 2008