



415-2007 ADDENDUM 2

FORT GARRY COMMUNITY CENTRE SKATEPARK

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: June 12, 2007
BY: Coleen Groening
TELEPHONE NO. (204) 986-2491

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

Revise: Section 03300, 2.1.1 to read: Portland Cement: to CAN/CSA-A5, normal Type 10, sulphate resistant type 50 (for ground contact as noted on drawings)

DRAWINGS

Replace:

415-2007 with_415-2007_Addendum_2-Drawing_Drawing_SK1.1-RC

415-2007 with_415-2007_Addendum_2-Drawing_Drawing_SK4.3-RB

415-2007 with_415-2007_Addendum_2-Drawing_Drawing_SK5.1-RB

415-2007 with_415-2007_Addendum_2-Drawing_Drawing_SK8.1-RC

415-2007 with_415-2007_Addendum_2-Drawing_Drawing_SK9.1-RB

415-2007 with_415-2007_Addendum_2-Drawing_Drawing_SK10.1-RB

415-2007 Drawing SK10.2-RB with_415-2007_Addendum_2-Drawing_Drawing_SK10.2-RC