


NOTES :


1. ALL LUMINAIRES SHALL COME COMPLETE WITH LAMPS AND MANITOBA HYDRO POWER SMART APPROVED BALLASTS.
2. CHAIN SUPPORTS FOR TYPE 6 LUMINAIRE SHALL NOT PENETRATE ROOF STRUCTURE. FASTEN CHAINS TO METAL CHANNEL FASTENED TO CEILING JOISTS.
3. REPLACE DUPLEX RECEPTACLE WITH COVER PLATE AND FLEX CONDUIT CONNECTOR FOR CONNECTION TO MODULAR FURNITURE WIRING HARNESS.
4. CIRCUIT NEW POWER POLES FROM CIRCUIT BREAKERS LEFT AS SPARE FROM RECEPTACLE DEMOLITION. CONFIRM LOCATION OF POLES WITH FURNITURE SUPPLIER.
5. REPLACE EXISTING LIGHTING SWITCHES WITH NEW EQUIPMENT, RELOCATE AND RECONNECT TO EXISTING LIGHTING CIRCUITS AS INDICATED.
6. CONNECT HEAT DETECTOR TO EXISTING F.A. SYSTEM. PROVIDE F.A. VERIFICATION TEST REPORT FOR ALL NEW DEVICES.



LUMINAIRE SCHEDULE					
TYPE	MANUFACTURER	CAT. No.	LAMP	VOLTAGE	REMARKS
1	BRYANT	5228	100W INCAND.	120V	MEDIUM BASE PORCELAIN BODY KEYLESS SUITABLE FOR MOUNTING ON A 100 (4") ROUND DEVICE BOX. C/W WIRE LAMP GUARD AND GROUNDING KIT
2	LITHONIA	TWR1C 100S 120 LPI CSA	100W HPS	120V	OUTDOOR WALLPACK UNIT. BRONZE FINISH 120V FULL CUTOFF
3	LITHONIA	BWX-232-120-GE8101S	2-32W T8	120V	SURFACE MOUNT FLUORESCENT C/W PRISMATIC LENS
4	AIMLITE	CXST6-36-1-W-2MD -WHT-ATD	2 MR16 8WQ	6V / 120V	WALL MTD. EXIT SIGN C/W 2 8W EMERG. LTG. LAMPS WITH INTEGRAL BATTERY UNIT
5	LITHONIA	C-232-120-GE8101S	4-32W T8	120V	8' SURFACE MOUNT FLUORESCENT STRIP LIGHT C/W ENAMEL WIRE GUARD AND ASYMMETRICAL REFLECTOR
6	LITHONIA	RIU-232-120-GE8101S-HC	2-32W T8	120V	CHAIN SUSPENDED INDUSTRIAL FLUORESCENT C/W UPLIGHT. MTD AT 3000 ABOVE FIN. FLOOR

D	ISSUED FOR TENDER	SCK	07/11/02
C	ISSUED FOR FINAL REVIEW	SCK	07/10/19
B	ISSUED FOR 100% REVIEW	SCK	07/08/12
A	ISSUED FOR CLIENT REVIEW	QL	07/08/17
NO.	REVISION/DESCRIPTION	BY	DATE

SEALS



DRAWN BY SCK CHECKED BY - APPROVED -
 DATE 2007.05.09 USER APPROVAL

CITY OF WINNIPEG
 PLANNING, PROPERTY &
 DEVELOPMENT DEPARTMENT
 CIVIC ACCOMMODATIONS DIVISION
 300 - 65 GARRY ST. R3C 4K4


PROJECT
 FORESTRY & LANDSCAPE DEVELOPMENT
 FACILITY ENHANCEMENT PROJECT

PROJECT ADDRESS

SHEET TITLE

ELECTRICAL
 OFFICE MAIN AND SECOND FLOOR
 NEW CONSTRUCTION

DRN	CHK	DES	ENG	IDR
UMA AECOM REVIEW				



SCALE 1:500 PROJECT NO. 0265-395-02 SHEET NO. OFF-E.2.1