

UMA Engineering Ltd.  
 1479 Buffalo Place  
 Winnipeg, Manitoba R3T 1L7  
 T 204.284.0580 F 204.475.3646 www.uma.aecom.com

## Memorandum

Date: January 17, 2008  
 To: Blair Moore  
 From: Faris Khalil  
 Subject: PRPS upgrades – Updated groundwater readings  
 Project Number: D265-202-02 (4.6.1)

Distribution: Steve Wiecek

As requested, find below the updated groundwater readings as of January 11, 2008 for the above referenced site:

| Test Hole  | Depth to water from ground surface, m | Approximate groundwater level, m |
|--|---------------------------------------|----------------------------------|
| TH07-01 (standpipe piezometer in Till unit)      | 3.92                                  | 234.4                            |
| TH07-04 ( 150 mm test well in limestone bedrock) | 4.99                                  | 234.8                            |

Please refer to UMA letter "Perimeter Road Pumping Station- 6821 Wilkes Avenue, Winnipeg, MB - Hydrogeologic Assessment Report" and UMA memo "Perimeter Road Sewage Pumping Station (PRPS) Reliability Upgrade -Geotechnical Investigation Report" both dated September 14, 2007 for test holes location and further discussion and recommendations with respect to groundwater.

Sincerely



Faris Khalil, M.Sc., P.Eng  
 Senior Geotechnical Engineer  
 Earth and Water