

FILE NAME: F863-001-01_01-E-8001_RV.dwg
 DATE: 2007.02.21
 DESCRIPTION: Second Floor Demolition
 PROJECT No: F863-001-01
 PLOT: 07/07/20 2:28:41 PM
 ADDRESS: 989 Sargent St. Winnipeg, Manitoba
 UMA FILE NAME: F863-001-01_01-E-8002_RV.dwg

PANEL 'CF'									
CCT NO	DESCRIPTION	LOAD	TRIP AMPS	N AB	TRIP AMPS	LOAD	DESCRIPTION	CCT NO	
01	GYMNASIUM / TRACK FLUOR. LTG.		15	•	15		WASHROOM / JANITOR RM. LTG.	02	
03	GYMNASIUM / TRACK FLUOR. LTG.		15	•		x		04	
05	GYMNASIUM / TRACK FLUOR. LTG.		15	•		x		06	
07	GYMNASIUM / TRACK FLUOR. LTG.		15	•		x		08	
09	GYMNASIUM / TRACK FLUOR. LTG.		15	•		x		10	
11	GYMNASIUM / TRACK FLUOR. LTG.		15	•		x		12	
13	GYMNASIUM / TRACK FLUOR. LTG.		15	•		x		14	
15	GYMNASIUM / TRACK FLUOR. LTG.		15	•		x		16	
17	GYMNASIUM / TRACK FLUOR. LTG.		15	•		x		18	
19	GYMNASIUM / TRACK FLUOR. LTG.		15	•		x		20	
21	GYMNASIUM / TRACK FLUOR. LTG.		15	•		x		22	
23	GYMNASIUM / TRACK FLUOR. LTG.		15	•		x		24	
25	x			•				26	
27	x			•				28	
29	x			•				30	
31	x			•				32	
33	x			•				34	
35	x			•				36	
37	x			•				38	
39	x			•				40	
41	x			•				42	

VOLTAGE: 120/208V PHASE: 3 WIRE: 4 BREAKER I.C.: 10kA
 MAIN BREAKER: - MAINS: 100A FEEDER: 4 #3 AWG R90 IN 35C
 MOUNTING: SURFACE LOCATION: 2ND FLOOR NORTH WALL
 FED FROM: -
 NOTES: -
 -
 -

PANEL 'CG'									
CCT NO	DESCRIPTION	LOAD	TRIP AMPS	N AB	TRIP AMPS	LOAD	DESCRIPTION	CCT NO	
01	WEST TELEVISION RECEPT.		15	•	15		ELEVATOR SERVICE RECEPT.	02	
03	WEST WATER COOLER CONNECTION		15	•			WASHROOM RECEPT.	04	
05	CENTRE EXERCISE AREA RECEPT.		15	•			SERVICE RECEPT.	06	
07	CENTRE EXERCISE AREA RECEPT.		15	•			SERVICE RECEPT.	08	
09	CENTRE EXERCISE AREA RECEPT.		15	•			TELEVISION RECEPT.	10	
11	WEST EXERCISE AREA RECEPT.		20	•	15		EAST WATER COOLER CONNECTION	12	
13			2P	•	15		LAP COUNTERS	14	
15	WEST EXERCISE AREA RECEPT.		20	•	15		EAST PARTION WALL RECEPT.	16	
17			2P	•	15		EAST PARTION WALL RECEPT.	18	
19	WEST EXERCISE AREA RECEPT.		20	•	15		EAST PARTION WALL RECEPT.	20	
21			2P	•	15		EAST PARTION WALL RECEPT.	22	
23	WEST EXERCISE AREA RECEPT.		20	•	15		LOCKER AREA RECEPT.	24	
25			2P	•	15		LOCKER AREA RECEPT.	26	
27	WEST EXERCISE AREA RECEPT.		20	•	15		JANITOR RM. RECEPT.	28	
29			2P	•	15		SPARE	30	
31	VENDING MACHINE RECEPT.		15	•	15		SPARE	32	
33	VENDING MACHINE RECEPT.		15	•	20		CARDIO AREA RECEPT.	34	
35	CARDIO AREA RECEPT.		20	•	20		WH-3 TRACK HOT WTR. HTR.	36	
37	CARDIO AREA RECEPT.		20	•			SPACE	38	
39	SPACE			•			SPACE	40	
41	SPACE			•			SPACE	42	


VOLTAGE: 120/208V PHASE: 3 WIRE: 4 BREAKER I.C.: 10kA
 MAIN BREAKER: - MAINS: 200A FEEDER: 4 #3/0 AWG R90 IN 53C
 MOUNTING: SURFACE LOCATION: -
 FED FROM: -
 NOTES: -
 -
 -

PANEL 'CH'									
CCT NO	DESCRIPTION	LOAD	TRIP AMPS	N AB	TRIP AMPS	LOAD	DESCRIPTION	CCT NO	
01	CRAWLSPACE LIGHTING		15	•	15		CRAWLSPACE RECEPT.	02	
03	CRAWLSPACE LIGHTING		15	•	15		CRAWLSPACE RECEPT.	04	
05	IRRIGATION CONTROL		15	•	15		CRAWLSPACE RECEPT.	06	
07	EXHAUST FAN F-5		15	•			SPACE	08	
09	SPACE			•			SPACE	10	
11	SPACE			•			SPACE	12	
13	SPACE			•			SPACE	14	
15	SPACE			•			SPACE	16	
17	SPACE			•			SPACE	18	
19	SPACE			•			SPACE	20	
21	SPACE			•			SPACE	22	
23	SPACE			•			SPACE	24	
25	SPACE			•			SPACE	26	
27	SPACE			•			SPACE	28	
29	SPACE			•			SPACE	30	
31	SPACE			•			SPACE	32	
33	SPACE			•			SPACE	34	
35	SPACE			•			SPACE	36	
37	SPACE			•			SPACE	38	
39	SPACE			•			SPACE	40	
41	SPACE			•			SPACE	42	

VOLTAGE: 120/208V PHASE: 3 WIRE: 4 BREAKER I.C.: 10kA
 MAIN BREAKER: - MAINS: 100A FEEDER: 4 #3 AWG R90 IN 35C
 MOUNTING: FLUSH LOCATION: EXIST. FACILITY 1ST FLOOR STAIRWELL
 FED FROM: -
 NOTES: -
 -
 -

PANEL 'CJ'									
CCT NO	DESCRIPTION	LOAD	TRIP AMPS	N AB	TRIP AMPS	LOAD	DESCRIPTION	CCT NO	
01	PENTHOUSE LIGHTING		15	•	15		PENTHOUSE SERVICE RECEPT.	02	
03	SERVICE SPACE LIGHTING		15	•	15		EXHAUST FAN EF-5	04	
05	SERVICE SPACE LIGHTING		15	•	15		PENTHOUSE EXTERIOR RECEPT.	06	
07	SERVICE SPACE RECEPT.		15	•	30			08	
09	EXHAUST FAN EF-1		15	•	3P		WINDOW WASH. EQUIP. RECEPT.	10	
11	EXHAUST FAN EF-2		15	•				12	
13	BOILER No.1		15	•	15		WINDOW WASH SERVICE RECEPT.	14	
15	BOILER No.2		15	•	15		ELEVATOR LIGHTING	16	
17	BOILER No.1 CIRCULATION PUMP		15	•	15		METASYS CONTROL MODULE	18	
19	BOILER No.2 CIRCULATION PUMP		15	•	15		DAMPER MOTOR DM-1	20	
21	SPACE			•	15		DAMPER MOTOR DM-2	22	
23	SPACE			•			SPACE	24	
25	SPACE			•			SPACE	26	
27	SPACE			•			SPACE	28	
29	SPACE			•			SPACE	30	
31	SPACE			•			SPACE	32	
33	SPACE			•			SPACE	34	
35	SPACE			•			SPACE	36	
37	SPACE			•			SPACE	38	
39	SPACE			•			SPACE	40	
41	SPACE			•			SPACE	42	


VOLTAGE: 120/208V PHASE: 3 WIRE: 4 BREAKER I.C.: 10kA
 MAIN BREAKER: - MAINS: 100A FEEDER: 4 #3 AWG R90 IN 35C
 MOUNTING: SURFACE LOCATION: PENTHOUSE
 FED FROM: -
 NOTES: -
 -
 -

UMA | AECOM
© 2007 UMA ENGINEERING LTD. ALL RIGHTS RESERVED.

 Certificate of Authorization
 UMA Engineering Ltd. (MB)
 No. 256 Date: Jul 23, 2007

DRN	CHK	DES	ENG	IDR

UMA | AECOM REVIEW

0	ISSUED FOR TENDER	QL	07/07/23
NO.	REVISION/DESCRIPTION	BY	DATE



DRAWN BY	QL	CHECKED BY	APPROVED
DATE	2007.02.21	USER APPROVAL	

CITY OF WINNIPEG
 PLANNING, PROPERTY & DEVELOPMENT DEPARTMENT
 CIVIC ACCOMMODATIONS DIVISION
 300 - 65 GARRY ST. R3C 4K4

PROJECT
**Construction of Cindy Klassen
 Recreation Complex Facility
 Enhancement Project**
 999 Sargent St. Winnipeg, Manitoba

SHEET TITLE		
Electrical Main, Second Floor and Penthouse Panel Schedules		
SCALE	PROJECT NO.	SHEET NO.
N.T.S.	2005-059	E8.2

DRAWING SHEET SIZE: A1 (841mm x 594mm) PLOT 1:1