



Corporate Finance
Department
Materials Management Branch

ADDENDUM 9 BID OPPORTUNITY 95-2007

WINNIPEG WATER TREATMENT PROGRAM – CONSTRUCTION OF OFFICES AND PLANT INTERIOR FINISHES

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: August 7, 2007
BY: Gord Smith, P. Eng.
TELEPHONE NO. (204) 986-4249

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20050506

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 10 of Form A: Bid may render your Bid non-responsive.

PART E - SPECIFICATIONS

DRAWINGS

WB-B0139

Clarification: Half height lockers are shown in room 344. All other lockers are required to be full height.

WM-S4111

Clarification: Delete requirement for CMU walls on the North and East side of the Fire Pump Room. These two walls will be completed by others.