


- GRAPHIC LEGEND**
- Parapet
 - Gas line
 - Gravel stop
 - Control joint
 - Expansion joint
 - New insulated drain pipe
 - Photo vantage point
 - Area Label
 - X = leak
 - ☒ = attic vent

- KEYNOTE LEGEND**
- 1 core sample
 - 2 chimney
 - 3 AC unit
 - 4 vent hood
 - 5 ventilator
 - 6 vent pipe
 - 7 roof drain
 - 8 skylight
 - 9 eavestrough
 - 10 firewall
 - 11 antenna
 - 12 ladder
 - 13 stub column
 - 14 roof hatch
 - 15 scupper
 - 16 pitch box
 - 17 HVAC unit
 - 18 capped curb
 - 19 flag pole
 - 20 electrical mast
 - 21 cooling tower
 - 22 splash pad
 - 23 splash pan
 - 24 downspout/rainwater leader
 - 25 back slope
 - 26 cant
 - 27 increase slope to drain
 - 28 cricket
 - 29 parapet/wide flashing
 - 30 life line anchor



A1 Construction (2008)
 T&G wood deck
 Soprema Sopravap'r
 2.5" Soprema Colgrip B
 2" Soprema Colgrip A
 Soprema Unilay cap sheet
 Insulation system mechanically fastened

B1 Construction (2008)
 plywood deck
 Soprema Sopravap'r
 1.5% sloped type 2 EPS (min 1")
 2" Soprema Colgrip A
 Soprema Colvent 810 base sheet
 Soprema Colvent 860 cap sheet
 Insulation system mechanically fastened

C1 Construction (2006)
 T&G decking
 1" expanded polystyrene (original)
 2 ply felt vapor barrier
 1.5% sloped type 2 EPS min 1"
 2" Soprema Colgrip A
 Soprema Colvent 810 base sheet
 Soprema Colvent 860 cap sheet
 Original 1" insulation was installed to fit around lots of conduit on decking. Insulation system was adhered with asphalt due to conduit.

Notes:
 .01 Contractor is responsible for site verifications of all dimensions
 .02 Drawings are not to be scaled for estimating purposes
 .03 All areas given are approximate
 .04 Contractor is responsible for site verification of existing roof constructions
 Stated scale is when in 11x17 format



809 Pipeline Road, Winnipeg, Manitoba
 Phone: 697-8091 Fax: 697-8039

Project: Billy Mosienko Arena
 700 Keewatin
 Winnipeg, MB

Date: January 27, 2008

Drawing No. R-1

File no: 3618-08 Scale: 1:300