



## 298-2008 ADDENDUM 4

### PROVISION OF INSPECTION AND TESTING OF SPRINKLER SYSTEMS AND FIRE ALARM SYSTEMS INCLUDING EMERGENCY LIGHTING

#### **URGENT**

**PLEASE FORWARD THIS DOCUMENT TO  
WHOEVER IS IN POSSESSION OF THE BID  
OPPORTUNITY**

ISSUED: April 2, 2009  
BY: Carmen Sorby  
TELEPHONE NO. (204) 986-3855

**THIS ADDENDUM SHALL BE INCORPORATED  
INTO THE BID OPPORTUNITY AND SHALL  
FORM A PART OF THE CONTRACT  
DOCUMENTS**

Template Version: A20070419

---

**Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.**

---

Please be advised the date of issuance for 298-2008 Addendum 3 should have read April 2, 2009.

#### **PART B – BIDDING PROCEDURES**

Revise: B10.3

- B10.3 The Bidder and/or any proposed Subcontractor (for the portion of the Work proposed to be subcontracted to them) shall:
- (a) have successfully carried out work similar in nature, scope and value to the Work; and
  - (b) be fully capable of performing the Work required to be in strict accordance with the terms and provisions of the Contract; and
  - (c) have a written workplace safety and health program, if required, pursuant to The Workplace Safety and Health Act (Manitoba);
  - (d) have licensed personnel conducting the annual inspection and testing of a Sprinkler System qualified in accordance with Fire Prevention By-law No. 150/2004 and Sprinkler System Installer must have a Sprinkler System Installer License issued by the Province of Manitoba.
  - (e) have licensed personnel conducting the annual inspection and testing of Fire Alarm Systems qualified in accordance with the Fire Prevention By-law No. 150/2004 and as set out in the Manitoba Fire Code Article 6.3.1.5.
  - (f) have licensed personnel conducting the annual inspection and testing of Emergency Lighting qualified in accordance with the Fire Prevention By-law No. 150/2004 as set out in the Manitoba Fire Code Article 6.3.1.5.
  - (g) have personnel providing the inspection and testing of special extinguishing systems (i.e. FM-200 Manual Fire Suppression System) be qualified in accordance with the Fire Prevention By-law No. 150/2004 which states:
    - (i) Service Personnel Qualifications: Set out in the Manitoba Fire Code Article 6.3.1.5. and employed by a company approved as an authorized service agency by any manufacturer of a gas-based fire suppression system
    - (ii) A license (as per by-law 150/2004) would be required.