



548-2008 ADDENDUM 1

Supply and Installation of Underground Fuel Storage Tanks and All Associated Equipment at 735 Assiniboine Park Drive

ISSUED: 2008-08-06
BY: Ben Vipond
TELEPHONE NO. (204) 986-8370

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph B5.3 of Form A: Bid may render your Bid non-responsive.

PART E – SPECIFICATIONS

- Revise: E2.1 (e) to read: The fuel tanks shall be capable and buried to a depth of 2.13 meters below grade.
- Add: E2.6 (g) Kiosk is to include the following
 - i. Electric base board heater that is thermostatically controlled
 - ii. Window type air conditioner that is thermostatically controlled
 - iii. One double bulb 48" florescent light fixture complete with bulbs
 - iv. One 200 amp service panel
 - v. 8 double plug outlets with location to be determined during construction.
 - vi. Kiosk will be located to the north of the fuel island by 30 meters
 - vii. Electrical service to the site is to be single phase with an independent meter to the kiosk.
- Revise: E2.7(d) to read: Commercial grade 8 foot high chain link fence is to be installed with a 1 meter perimeter around the generator. The fence is to be complete with 2 (two) gates, complete with white privacy plastic strips.
- Add: E2.7 (e) Generator is to be bolted to a 150mm concrete pad
- Add: E2.11 All concrete is to be constructed with accordance to section 5 and 6 of cw3310 in accordance with the CSA A23.1, Alternative (1) for specifying concrete, the concrete mix shall be proportioned such as to yield concrete having the required strength and workability as follows:
 - i. Class of Exposure: C-2 ii. Minimum Specified Compressive Strength @ 28 days = 32 MPa
 - iii. Minimum Cementitious Content = 340 kg/m³
 - iv. Maximum Water/Cementitious Ratio = 0.45
 - v. Slump = 50 ± 20 mm (for slip form paving)

= 70 ± 20 mm (for hand placement)

vi. Aggregate Size = 20 mm Nominal Air Content = 5.0% to 8.0 %

- Add: E2.12 The Contractor shall place reinforcing steel in accordance with Section 9 of CW 3310.
- Add: E2.13 Concrete fuel pad is to be 250 mm thick and conform to specifications E2.11 and E2.12