



MH ID S-MH50003290
 MH OPENING - 521Ø
 MH RISERS - 750Ø
 MH BASE - 1200Ø

MH ID S-MH50003291
 MH OPENING - 521Ø
 MH RISERS - 750Ø
 MH BASE - 1200Ø

45.10 OF 300 CONC CS TO BE LINED
 SEWER ID S-MA50003808

45.1 PARTIALLY DETERIORATED
 OVALITY = 3.0%

2.0 OF 300 SDR 35 PVC
 SEWER REPAIR (SD-022A)
 TO BE DONE BY OTHERS

SEWER JUNCTION INFORMATION FROM SEWER VIDEO INSPECTION S-MA50003808				
DISTANCE FROM MH S-MH50003290				
23.4	N	150Ø	EAST	CN
28.7	N	150Ø	WEST	CNI
32.5	N	150Ø	EAST	CN
42.1	N	150Ø	EAST	CNI

ENGINEER'S SEAL

ORIGINAL
 SIGNED BY
 S.R.J.
 COURNOYER
 09/01/08

BID OPPORTUNITY: 924-2008
 FILENAME : 8775.dwg
 PLOT DATE : 2009 01 08

METRIC
 WHOLE NUMBERS INDICATE MILLIMETRES
 DECIMALIZED NUMBERS INDICATE METRES

B.M. ELEV.	FIELD BOOK #:	CITY OF WINNIPEG WATER AND WASTE ENGINEERING DIVISION			THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT
POSTED TO LIS		DESIGNED BY: SC	CHECKED BY: SC		
		DRAWN BY: C.JH/WKT	APPROVED BY: KZ	SHEET 14 OF 34 CITY DRAWING NUMBER 8775	
		HOR. SCALE: 1:500 VERTICAL	RELEASED FOR CONSTRUCTION		
NO.	REVISIONS	DATE	BY	DATE: 2009 01 08	DATE