



429-2009 ADDENDUM 2

Supply and install fuel tanks and retrofit existing fuel tanks at various city owned golf fuel sites

URGENT

PLEASE FORWARD THIS DOCUMENT TO WHOEVER IS IN POSSESSION OF THE BID OPPORTUNITY

ISSUED: July 3, 2009
BY: Ajaleigh Williams
TELEPHONE NO. (204) 986-7879

THIS ADDENDUM SHALL BE INCORPORATED INTO THE BID OPPORTUNITY AND SHALL FORM A PART OF THE CONTRACT DOCUMENTS

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART B – BIDDING PROCEDURES

Revise: B2.1 to read: The Submission Deadline is 4:00 p.m. Winnipeg time, July 8, 2009.

PART E – SPECIFICATIONS

Revise: E2.3 (b) (i) to read: The Contractor shall backfill the excavation with clean fill to 150 mm below finished grade. The Contractor shall bid on removing 180 m³ of contaminated soil and replacing with 180 m³ of clean fill. If upon excavation it is determined that the soil is not contaminated, the Contractor shall use the existing clean fill from the excavation as backfill and this cost shall no longer be applied. The fill will be placed in 300 mm lifts and compacted to 100 % Proctor Density.