


Summary Bill of Materials

NOTE THAT ALL PERIPHERAL DEVICES WERE SUPPLIED BY THE CUSTOMER. ONLY THE DDC CONTROLLERS AND THE IDEC RELAYS ARE NEW DEVICES.

Summary Bill of Materials				
DID	DESCRIPTION	MANUFACTURER	PART NUMBER	QTY
AAR	ARCNET TO ARCNET ROUTER	AUTOMATED LOGIC	AAR	1 ea
CR-1	24VAC DPDT RELAY	OMRON	LY2-US24	2 ea
CR-2	24VAC DPDT RELAY	OMRON	LY2-US24	2 ea
CR-3	24VAC DPDT RELAY	OMRON	LY2-US24	1 ea
CT-1	CURRENT SENSOR (FAN STATUS)	UNKNOWN	CT	1 ea
DPS-1	DIFFERENTIAL PRESSURE SENSOR (FAN STATUS)	UNKNOWN	P32AF-2	1 ea
DPT-1	DIFF. PRESS. TRANSDUCER (0-2 WC / 4-20MA)	INNOVEX	600D 2 12D	1 ea
EH-7	HOFFMAN NEMA 1 24X20X6.25	HOFFMAN	A-24N20ALP	1 ea
LGR25	LGR25	AUTOMATED LOGIC	LGR25	1 ea
M4106	M4106	AUTOMATED LOGIC	M4106	1 ea
MX16160	MX16160	AUTOMATED LOGIC	MX16160	3 ea
NO2	NO2 GAS SENSOR	ARMSTRONG	AMC-V6200	2 ea
PS-1	24VDC POWER SUPPLY (ADJUSTABLE)	GREYSTONE	241F	2 ea
PS-2	12VDC POWER SUPPLY (ADJUSTABLE)	GREYSTONE	241F	2 ea
R-1	24VAC DPDT RELAY	OMRON	LY2-US24	2 ea
R-2	24VAC DPDT RELAY	OMRON	LY2-US24	2 ea
R-3	24VAC DPDT RELAY	OMRON	LY2-US24	1 ea
R-4	24VAC DPDT RELAY	OMRON	LY2-US24	1 ea
REL-B	DPDT RELAY W/ IND LGHT 24 VAC	IDEC	RH2B-ULC-AC24V	33 ea
SE6104	SE6104	AUTOMATED LOGIC	SE6104	26 ea
TE1	SPACE TEMPERATURE SENSOR (1000 OHM)	JOHNSON	TE-6000-4	2 ea
TE2	SUPPLY AIR TEMPERATURE SENSOR (1000 OHM)	JOHNSON	TE-6000-4(-1)	2 ea
TE3	OUTSIDE AIR TEMPERATURE SENSOR (1000 OHM)	JOHNSON	TE-6000-4	1 ea
TRV150	120/24 VAC TRANSFORMER 150VA WITH BREAKER	VERIS IND	X150CAA	1 ea
TRV75	120/24 VAC TRANSFORMER 75VA WITH BREAKER	VERIS IND	X075CAA	1 ea
VRT-1	VOLTAGE IN / RESISTANCE OUT TRANSDUCERS	ADVANCED TECH.	DRN2	3 ea
X-1	600-24VAC 100VA CONTROL TRANSFORMER	HAMMOND	EG9G	3 ea

Winnipeg Transit Winnipeg, Manitoba			
Integrated Control Systems			
Summary Bill of Materials			
REV: 1	As-Built	5/29/2008	JOB NO: ICS06-81
			CHECK BY: JJJ
			DSCODE:
			4 of 27