

WILDWOOD H PK W. LEG

SEWER SERVICE INFORMATION (S-MA60013272) *

DISTANCE FROM 1ST MH N OF SOUTH DR (S-MH60011472)	
6.6 S	SERVICE CONNECTION W
7.4 S	SERVICE CONNECTION E
13.2 S	SERVICE CONNECTION W
22.5 S	SERVICE CONNECTION E
24.6 S	SERVICE CONNECTION W
25.4 S	SERVICE CONNECTION E
44.1 S	SERVICE CONNECTION W
45.6 S	SERVICE CONNECTION E
45.7 S	SERVICE CONNECTION E

* - INFORMATION FROM SEWER VIDEO INSPECTION

SEWER SERVICE INFORMATION (S-MA60013330) *


DISTANCE FROM 1ST MH N OF SOUTH DR (S-MH60011472)	
10.2 N	SERVICE CONNECTION W
11.0 N	SERVICE CONNECTION E
28.9 N	SERVICE CONNECTION E
29.0 N	SERVICE CONNECTION W
47.0 N	SERVICE CONNECTION W
53.3 N	SERVICE CONNECTION E
62.6 N	SERVICE CONNECTION W
67.3 N	SERVICE CONNECTION E
72.0 N	SERVICE CONNECTION W

* - INFORMATION FROM SEWER VIDEO INSPECTION

- CONSTRUCTION NOTES:**
- CONTRACTOR SHALL TAKE PRECAUTIONARY STEPS TO AVOID DAMAGE FROM CONSTRUCTION ACTIVITIES TO EXISTING BOULEVARDS AND TREES WITHIN THE LIMITS OF CONSTRUCTION.
 - SEWER AND SEWER SERVICES TO BE INSTALLED BY TRENCHLESS METHODS UNLESS OTHERWISE SPECIFIED.
 - LOCATION OF EXISTING UTILITIES TO BE CONFIRMED IN THE FIELD BY THE CONTRACTOR.
 - LIMITS OF SIDEWALK RENEWALS TO BE FINALIZED IN THE FIELD BY THE CONTRACT ADMINISTRATOR.
 - BOULEVARD REPLACEMENT TO BE FINALIZED IN THE FIELD BY THE CONTRACT ADMINISTRATOR.
 - CONTRACTOR TO PLUG ANY ABANDONED PIPES THAT ARE BROKEN DURING CONSTRUCTION.
 - TRENCHES & EXCAVATIONS WITHIN 1 METRE OF A PAVED AREA INCLUDING SIDEWALKS SHALL BE CLASS 3 BACKFILL.
 - BACKFILL IN BOULEVARD TO BE CLASS 5.
 - CB LEADS TO BE INSTALLED AT MIN. 1.0% SLOPE OR AS DIRECTED BY CONTRACT ADMINISTRATOR.
 - CONTRACTOR TO CONFIRM THE NUMBER AND LOCATION OF SEWER SERVICES TO BE RECONNECTED.

- GENERAL NOTES**
- CONTRACTOR TO VERIFY LIMITS OF SEWER REPAIRS PRIOR TO EXCAVATION BY MEANS OF VIDEO INSPECTION.
 - CONTRACTOR TO ASSIST WITH VISUAL INSPECTION OF EXISTING SERVICES TO DETERMINE IF SERVICE RENEWAL IS REQUIRED.

METRIC
WHOLE NUMBERS INDICATE MILLIMETRES
DECIMALIZED NUMBERS INDICATE METRES



150 mm W.M.	150 mm W.M.	150 mm W.M.	150 mm W.M.	150 mm W.M.	150 mm W.M.	150 mm W.M.
HYDRANT VALVE	HYDRANT VALVE	HYDRANT VALVE	HYDRANT VALVE	HYDRANT VALVE	HYDRANT VALVE	HYDRANT VALVE
LAND DRAINAGE SEWER	LAND DRAINAGE SEWER	LAND DRAINAGE SEWER	LAND DRAINAGE SEWER	LAND DRAINAGE SEWER	LAND DRAINAGE SEWER	LAND DRAINAGE SEWER
WASTE WATER SEWER	WASTE WATER SEWER	WASTE WATER SEWER	WASTE WATER SEWER	WASTE WATER SEWER	WASTE WATER SEWER	WASTE WATER SEWER
MANHOLE	MANHOLE	MANHOLE	MANHOLE	MANHOLE	MANHOLE	MANHOLE
CATCH BASIN	CATCH BASIN	CATCH BASIN	CATCH BASIN	CATCH BASIN	CATCH BASIN	CATCH BASIN
CURB INLET	CURB INLET	CURB INLET	CURB INLET	CURB INLET	CURB INLET	CURB INLET
JUNCTIONS	JUNCTIONS	JUNCTIONS	JUNCTIONS	JUNCTIONS	JUNCTIONS	JUNCTIONS
CULVERT	CULVERT	CULVERT	CULVERT	CULVERT	CULVERT	CULVERT
GAS	GAS	GAS	GAS	GAS	GAS	GAS
EXISTING	LEGEND-PLAN	PROPOSED	EXISTING	LEGEND-PLAN	PROPOSED	EXISTING

UNDERGROUND STRUCTURES

NO.	REVISIONS	DATE	BY
0	ISSUED FOR TENDER	10/07/2009	S.C.C.

DESIGNED BY: C.L.P.
DRAWN BY: A.J.P.
CHECKED BY: S.C.C.
APPROVED BY: D.P.K.
HOR. SCALE: 1:500
VERTICAL: _____
RELEASED FOR CONSTRUCTION: _____
DATE: AUG. 26, 2009

DILLON CONSULTING

THE CITY OF WINNIPEG WATER AND WASTE DEPARTMENT

2009 SEWER RENEWALS AND REPAIRS, CONTRACT 19
WILDWOOD H PK (W.LEG)
1ST MH S OF WILDWOOD H PK (N LEG) TO 1ST MH N OF SOUTH DR AND 1ST MH N OF SOUTH DR TO MH AT SOUTH DR

CITY DRAWING NUMBER: 9109
SHEET: 24 OF 25
BID OPPORTUNITY: 658-2009

CONSULTANT PROJECT NO.: 09-1893-2000