



GRIT AREA ELECTRICAL ROOM
1:50

CONSTRUCTION NOTES	
1	PROGRAM EXISTING WESTINGHOUSE IQ DATA PLUS II VOLTAGE MONITORING AND PROTECTION UNIT ON MCC-1G AND MCC-2G, AND CONNECT TO DCS PCU SA.
2	REMOVE NORMAL EMERGENCY SELECTOR SWITCH AND MODIFY WIRING AS SHOWN ON THE LOOP DIAGRAMS.

NOTES:
1. THIS DRAWING IS BASED ON THE EXISTING LAYOUT OF THE ELECTRICAL ROOM.



NO.	REVISIONS	DATE	DESIGN	CHECK
00	ISSUED FOR TENDER, BID OPP: 837-2009	2009/12/07	NB	CJR

DESIGNED BY: EXISTING/N.BRADOO	CHECKED BY: C. REIMER
DRAWN BY: E. BOHNCKE	APPROVED BY: C. REIMER
SCALE: 1:50	RELEASED FOR CONSTRUCTION BY: J. VEILLEUX
DATE: 2009/12/07	DATE: 2009/12/02
CONSULTANT NO.: 112577-0105-47DD-0103	

ENGINEER'S SEAL

ORIGINAL DRAWING
SEALED BY:
N. BRADOO
SNC-LAVALIN
2009/12/07
REV. 00
CONSTRUCTION
NOTES ONLY

THE CITY OF WINNIPEG
WATER AND WASTE DEPARTMENT

SOUTH END WATER POLLUTION CONTROL CENTRE
ELECTRICAL INSPECTION & UPGRADES
PLAN LAYOUT
GRIT BUILDING ELECTRICAL ROOM

CITY DRAWING NUMBER	SHEET	REV.	SIZE
1-0102G-E0007	001	00	A1

DRAWING NUMBER	REFERENCE DRAWINGS
----------------	--------------------