


**1 ROOF PLAN - ELECTRICAL LAYOUT**  
 E3.0 SCALE: 1:100

**NOTES:**  
 1. PROVIDE RAYCHEM SELF-REGULATING HEAT TRACE FOR FIRST 10'-0" OF PIPING FROM ROOF DRAIN. COORDINATE INSTALLATION WITH MECHANICAL.



D ISSUED FOR TENDER	FEB 26, 2010
C ISSUED FOR 99% REVIEW	FEB 10, 2010
B ISSUED FOR 90% REVIEW	JAN 08, 2010
A ISSUED FOR 60% REVIEW	DEC 02, 2009

This drawing must not be scaled.

The general Contractor must verify all dimensions, datums and levels prior to commencement of work. All errors and omissions must be reported immediately to the Architect.

Variations and modifications to work shown on this drawing shall not be carried out without written permission from the Architect.

This drawing is the exclusive property of the Architect and cannot be reproduced without written permission of the Architect. Reproduction must bear the name of the Architect. Copyright © 2009.



**project**  
**SINCLAIR COMMUNITY CENTRE ADDITION & RENOVATIONS**  
 490 Sinclair Street, Winnipeg

**sheet title**  
**ROOF PLAN - ELECTRICAL LAYOUT**

project number: 5878	drawing number: <b>E3.0</b>
scale: N.T.S.	
drawn by: PAS	
approved by: GSR	
date: 2010-02-26	