


**1 MECHANICAL ROOF PLAN**  
**M6.1 SCALE: 1:100**

**GENERAL NOTES:**

1. THIS DRAWING IS DIAGRAMMATIC ONLY. DO NOT SCALE.
2. ALL MECHANICAL ROOF EQUIPMENT (MUA, EXHAUST FANS, CONDENSING UNITS, ETC.) TO BE RAISED 600MM (2') ABOVE ROOF.

**DRAWING NOTES:**

- ① 300X200 COMBUSTION DUCT C/W GOOSENECK. REFER TO DETAIL #5/M6.1.
- ② VENT FROM BOILERS IN BASEMENT.
- ③ VENT FROM DHWT-1 IN BASEMENT.
- ④ 1000X760 EXHAUST GOOSENECK FROM EF-2.
- ⑤ 1500X1500 EXHAUST GOOSENECK WITH SCREEN.
- ⑥ 150# EXHAUST GOOSENECK FROM RANGE HOOD (RH-1).
- ⑦ 150X150 EXHAUST FAN FROM BELOW. REFER TO DETAIL #3/M6.1.
- ⑧ 1000X760 OUTDOOR AIR DUCT TO AHU-2.
- ⑨ 1500X1500 OUTDOOR INTAKE GOOSENECK WITH SCREEN.



D ISSUED FOR TENDER FEB 26, 2010  
 C ISSUED FOR 99% REVIEW FEB 10, 2010  
 B ISSUED FOR 90% REVIEW JAN 08, 2010  
 A ISSUED FOR 60% REVIEW DEC 02, 2009

This drawing must not be scaled.

The general Contractor must verify all dimensions, datums and levels prior to commencement of work. All errors and omissions must be reported immediately to the Architect.

Variations and modifications to work shown on this drawing shall not be carried out without written permission from the Architect.

This drawing is the exclusive property of the Architect and cannot be reproduced without written permission of the Architect. Reproduction must bear the name of the Architect. Copyright © 2009.

**MCW / AGE**  
 Consulting Professional Engineers  
 210-1821 Wellington Avenue  
 Winnipeg, Manitoba, R2H 0G4  
 Phone: (204) 779-7900 Fax: (204) 779-1119  
 E-Mail: mcw\_age@mcw.com  
 5878

**harold funk** architect inc.

Harold Funk Architect Inc.  
 Architecture and Urban Design  
 401-55 Donald Street, Winnipeg, Manitoba, R3C 1L8  
 T (204) 943-5087 info@funkarchitect.com  
 F (204) 949-9231 funkarchitect.com

project  
**SINCLAIR COMMUNITY CENTRE ADDITION & RENOVATIONS**  
 490 Sinclair Street, Winnipeg

sheet title  
**MECHANICAL ROOF PLAN**

project number: 5878 drawing number:  
 scale: N.T.S. **M6.1**  
 drawn by: KLG  
 approved by: GSR  
 date: 2010-02-26