



743-2010 ADDENDUM 1

LIVING PRAIRIE MUSEUM PLAYGROUND REDEVELOPMENT

URGENT

**PLEASE FORWARD THIS DOCUMENT TO
WHOEVER IS IN POSSESSION OF THE BID
OPPORTUNITY**

ISSUED: February 7, 2011
BY: Shauna Prociuk
TELEPHONE NO. (204) 986-3938

**THIS ADDENDUM SHALL BE INCORPORATED
INTO THE BID OPPORTUNITY AND SHALL
FORM A PART OF THE CONTRACT
DOCUMENTS**

Template Version: A20070419

Please note the following and attached changes, corrections, additions, deletions, information and/or instructions in connection with the Bid Opportunity, and be governed accordingly. Failure to acknowledge receipt of this Addendum in Paragraph 8 of Form A: Bid may render your Bid non-responsive.

PART A – BID SUBMISSION

Replace: 743-2010 Bid Submission with 743-2010 Addendum 1- Bid Submission. The following is a summary of changes incorporated in the replacement Bid Submission:

- Form B(R1): Revise: Item 2 Quantity to 42LM
- Add: Item 10: "Supply and Install 2 tiered timber edging" - Quantity: 35 LM

PART E – SPECIFICATIONS

- Revise: E10.2.4 to read: Single tiered timber edging shall be installed as per Detail SCD-651 for approximately 42 LM of length at high end of Play Area transitioning into 2 tiered pressure treated timber edging for 35 LM of length at the low end of Play Area. Base course timbers shall be pinned with a minimum of two (2) 19mm diameter by 500mm rebar at maximum 1200mm O.C.. Contract Administrator to identify on site with contractor, the transition from single tiered to 2 tiered timber edging.
- Add: E10.3.1 (a) (ii) "Supply and Install 2 tiered timber edging" on Form B: Prices
- Revise: E12.1.3 (a) to read: Wood Fibre shall be installed within the Play Area, as shown on Drawings, to a minimum depth of 300mm (after compaction).
- Revise: E16.2.1 to read: Landscape Structures Inc., Model # 117962B series Infant Swing or approved substitute in accordance with B6. Single Leg, two (2) full bucket seats, heavy duty chains angled to prevent side-sway.
- Revise: E16.3.2 (a) to read: Leg shall be fabricated from min (5") O.D. galvanized steel pipe. All fabrication cuts, drill holes and weld joints shall be sprayed with a corrosion resistant coating and the bottom end of the posts shall be sealed with a moisture barrier.
- Revise: E16.3.8 to read: Foundations for swings as per manufacturer's specifications.

DRAWINGS

Replace: 743-2010 _Drawing_L-6_A2-R0 with 743-2010_Addendum_1 Drawing_L-6-A2-R1