



NOTES:
CROSS HATCHED PIPES REPRESENT SLUDGE PIPES TO AND FROM WEIR BOXES.
ALL DRIP TRAPS ARE TO BE DRAINED TO NEAREST HUB DRAIN.
ALL PIPES PASSING FROM THE GAS EQUIPMENT ROOM TO NON EXPLOSION PROOF AREAS TO HAVE A PUDDLE FLANGE AND TO BE SEALED IN THE WALL.

FOR ACTUAL ELEV. SUBTRACT 0.37 FT.

REVISIONS	
NO.	DATE

THE METROPOLITAN CORPORATION OF GREATER WINNIPEG
WATERWORKS AND WASTE DISPOSAL DIVISION

NORTH END SEWAGE TREATMENT PLANT

CONTRACT A - GAS EQUIPMENT ROOM & CONTROL HOUSE - MECHANICAL SECTIONS & DETAILS

REVISED
J. W. MacLAREN
REGISTERED ENGINEER

REVISED
J. L. GREER
REGISTERED ENGINEER

APPROVED
James F. MacLaren Limited
ENGINEERS TORONTO

APPROVED
W.L. Wardrop Associates (Management) Limited
ENGINEERING CONSULTANTS WINNIPEG

DATE: MARCH 11, 1963
SCALE: AS SHOWN
DWG. No. 136 OF 217
NEP-136